

- A 3 INCH METER SET REQUIRES A 4 INCH MINIMUM GATE VALVE AT THE MAIN AND A 4 INCH MINIMUM SUPPLY LINE.
- 2. 3 INCH METER SETS USE 1-1/2 INCH BY-PASS. 4 INCH METER SETS USE 2 INCH BY-PASS.
- 3. BLUE TRACER WIRE (SEE DWG. C-1.2.1) SHALL BE TAPED EVERY 5 FEET TO PIPE; EXTEND FROM MAIN TO A MINIMUM OF 48 INCHES INTO BOX.
- 4. PROVIDE CHRISTY B52 BOX WITH M3 LID. WHEN A LOCATION OUTSIDE OF PAVEMENT IS NOT POSSIBLE PROVIDE AN H20 TRAFFIC RATED BOX WITH AN H20 TRAFFIC RATED READING LID.
- 5. STEEL PIPE SHALL BE PRIMED AND WRAPPED, MIN 10 MILS (CONFORMING TO SSPWC SECTION 203.07.04)
- 6. STRAINER, SWING CHECK VALVE AND ALL GATE VALVES (EXCEPT GATE VALVE AT MAIN) SHALL BE FLGXFLG, F.C.A'S SHALL BE RESTRAINING TYPE, ROMAC OR APPROVED EQUAL. ALL NUTS, BOLTS & WASHERS SHALL BE TYPE 18-8 STAINLESS STEEL (304 OR 304L).

١	NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
ſ					CARSON CITY
İ				3" AND 4"	DRAWING NO. C-3.2.6 (203, 307)
ļ				SERVICE & METER SET	DATE (203, 307)
Į	APPRO'	VED BY:	7/09	SERVICE & METER SET	7/2009