

NOTES:

TYPICAL SECTION

- 1. CENTER CHECK VALVE IN VAULT.
- MANHOLE FRAME AND COVER TO BE SOUTH BAY FOUNDRY "SBF 1900 CPH" (CLOSED PICK HOLE) OR EQUAL AND SHALL BE MARKED "WATER".
- COMPACT TOP 6 INCHES SUBGRADE TO 90% M.D.D. PRIOR TO PLACING BACKFILL.
- 4. CHECK VALVES 12 INCHES OR LARGER REQUIRE SPECIAL DESIGN AND APPROVAL THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
- 5. MANHOLES SHALL BE WATER-TIGHT.
- 6. CHECK VALVES INSTALLED ON PRIVATE FIRE HYDRANT LINES ARE OWNED, OPERATED AND MAINTAINED BY THE PROPERTY OWNER

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
				CARSON CITY
			CHECK VALVE	DRAWING NO. C-3.3.1 (203,307)
				DATE
APPRO\	VED BY:	7/2009		