



6" CLASS "C" BACKFILL OR AGGREGATE BASE (SSPWC 200.03.04 & 200.01) COMPACTED TO 95% 1

TYPICAL SECTION
NTS

NOTES:

1. MUELLER 18 INCH LOCKING LID (PART No. TRPL-780113) AND 27 INCH x 18 INCH FRAME.
2. MUELLER EZ-Vault METER SETTER-RIGID PVC, FACTORY EQUIPPED AS SHOWN, CONFORMING TO AWWA C800.
3. WATER METER SHALL BE NO MORE THAN 30 INCHES FROM TOP OF LID AND NOT LESS THAN 24 INCHES FROM TOP OF LID.
4. A 2 INCH METER SET REQUIRES A 2 INCH MINIMUM SERVICE LINE.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	CHECK VALVE	05/14	<h1 style="margin: 0;">1 1/2" - 2"</h1> <h2 style="margin: 0;">PIT SETTER</h2>	CARSON CITY
				DRAWING NO. C-3.2.5 (203,307)
				DATE 5/2014
APPROVED BY:				