



NOTES:

1. ALL FITTINGS SHALL COMPLY WITH ANSI/NSF 372 REGARDING LOW LEAD CONTENT.
2. EXTEND TRACER WIRE AT LEAST 48" INTO METER BOX.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
			1 1/2" - 2" METER SET (TRAFFIC RATED)	CARSON CITY
				DRAWING NO. C-3.2.5.1 (203, 307)
				DATE 5/2014
APPROVED BY: <i>DB</i>		05/14		