



NOTES:

1. SERVICE LINES SHALL BE CTS POLYETHYLENE TUBING (CONFORMING TO SSPWC 203.16.02) WITH TUBING LINERS AS PER FITTING MANUFACTURER'S INSTRUCTIONS.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION CARSON CITY
			3/4" DUAL METER SET (H2O TRAFFIC RATED)	DRAWING NO. C-3.2.3.2 (203, 307)
				DATE 5/2014
APPROVED BY:		05/14		