

**CARSON CITY PURCHASING AND CONTRACTS**  
**201 North Carson Street, Suite 3**  
**Carson City, NV 89701**  
**775-283-7137/FAX 887-2107**  
**<http://www.carson-city.nv.us/index.aspx?page=998>**

**NOTICE TO CONTRACTORS**  
**RFQ #1011-154**  
**C.D.B.G. ADA Compliant Restrooms at the Community Center**  
**PWP # 1.0808**  
**Labor Commissioner PWP# CC-2011-46**

November 15, 2010

Addendum No. 2

Please make the following additions/changes to the above referenced project.

Answers to questions raised during bidding.

- 1) May I ask you to request to the architect to request to the mechanical engineer to please specify a trap primer for the fixture schedule. **Plans already call for the trap primer specification shown on trap primer detail on sheet P2.1**
- 2) The Demo drawings and Demo Schedule call for the existing electric hand dryers to be reused in the remodel. The Toilet Accessory Specs. on Sheet A300 call for a specific brand and model #. Are the existing ones to be reused? **Yes, the hand dryer specification is the same as the dryers to be reused.**
- 3) The Toilet Accessory Schedule on Sheet A300 calls for a Bobrick mirror to be 32"x 42". This is a special order size. Would a standard size 24"x 48" be acceptable? **Yes**
- 4) What walls receive the FRP wainscot? **8/A200 Finish Schedule calls out locations of FRP, all walls in a room that are called out Room Finish Type "A"**

**Make the following changes to the Bid Documents:**

- 1) N/A

**Make the following changes to the Plans:**

- 1) N/A.

**Clarifications:**

1) N/A

End of Addendum No. 2