

Number	Date Received	Name	Phone Email Written	Organization	Question/Comments	Response	Date of Response	Response By	Addenda Required	Addendum No. (If Required)
1	11/23/2010	Jeff Bean	e-mail	Q&D	Is it acceptable to turn in only pages BP-1 through BP-20 as the contractor's bid proposal?	Yes	11/23/2010	City	No	
2	11/23/2010	Jeff Bean	e-mail	Q&D	Pages BP 11 and BP 15 both require the submitting contractor to list the subcontractors in excess of 5%. Can Carson City delete one of these pages from the proposal package since they both provide essentially the same information?	Provide both forms for this project	11/23/2010	City	No	
3	11/23/2010	Jeff Bean	e-mail	Q&D	Pages BP 12 and BP 14 both require the submitting contractor to list the subcontractors in excess of 1%. Can Carson City delete one of these pages from the proposal package since they both provide essentially the same information?	Provide both forms for this project	11/23/2010	City	No	
4	11/23/2010	Jeff Bean	e-mail	Q&D	Page BP 18 requires the submitting contractor to itemize MBE/WBE procurements during the "Reporting Quarter." It has been our experience that this form is completed while contract work is being performed. Since submitting contractors will not have any purchases to report for the North Lift Pump Station project, what information should be included on page BP 18?	Provide completed forms during construction	11/23/2010	City	No	
5	11/23/2010	Jeff Bean	e-mail	Q&D	Page BP 19 also appears to be a quarterly report. What information should be provided on this form?	Provide completed forms during construction	11/23/2010	City	No	
6	11/23/2010	Jeff Bean	e-mail	Q&D	<b>Contract Award</b> Section CA 11 on page CA 5 indicates that the contractor has 15 days from contract award to turn in all submittals or Liquidated Damages will be charged. This is also stated on page GC 31 section 4.3.4. On page SC-1 section SC 8, it states that the contractor will have 90 days from the notice to proceed to provide all submittals. Which section will control?	Will be clarified by addendum	11/23/2010	JBR	Yes	No. 2
7	11/23/2010	Jeff Bean	e-mail	Q&D	<b>Special Conditions</b> Section SC 1 on page SC-1 indicates the contractor will need to carry "...not less than <b>One Million Dollars (\$5,000,000)</b> per occurrence..." for explosion, collapse, and underground insurance. Is a \$1M or \$5M per occurrence policy going to be required?	Will be clarified by addendum	11/23/2010	JBR	Yes	No. 2
8	11/23/2010	Jeff Bean	e-mail	Q&D	<b>Attachment C</b> Section 01450 Quality Control subsection 1.06C.1.a states "...soil compaction test and other specified tests shall be paid for by Contractor." Section 02318 Trenching subsection 3.03A.1.a.3 states "Cost of Confirmation Tests: Paid for by the Owner." Will compaction testing and other QC functions be provided by the contractor or the owner?	Will be clarified by addendum	11/23/2010	JBR	Yes	No.2

9	11/23/2010	Jeff Bean	e-mail	Q&D	Is a site trailer/office required for the General Contractor's use? Page C97 section 1.08 indicates that a field office will be maintained. Statements on pages GC-51 (GC7.6) and SC-2 (SC 12) indicate that contractors with home offices in the Carson/Reno/Sparks area will not be required to maintain a site office.	Will be clarified by addendum	11/23/2010	JBR	Yes	No. 2
10	11/23/2010	Jeff Bean	e-mail	Q&D	Is a site office for the owner's representative required to be provided by the contractor?	No	11/23/2010	JBR	No	
11	11/23/2010	Jeff Bean	e-mail	Q&D	Section 1500.1.03.D requires the contractor to provide a coin-operated telephone for the general use of the public. Can this be deleted from the specifications?	Will be clarified by addendum	11/23/2010	JBR	Yes	No. 2
12	11/23/2010	Jeff Bean	e-mail	Q&D	On page C-25, a schedule of values submittal is discussed. Section 1.02.D.1 indicates that mobilization and demobilization will have maximum values. Do these values affect the amount that a contractor can utilize for a price on bid item BP.1 on Page BP-2 for "Mobilization, Demobilization, and Clean-up?" What is the maximum percentage of TBP that can be bid for BP.1?	Per Section 1292, Part 1.02 D 1, a maximum of 5% of TBP for mobilization and 3% of TBP for demobilization and site maintenance or 'clean-up' is allowed.	11/23/2010	JBR	No	
13	11/23/2010	Jeff Bean	e-mail	Q&D	Section 1770 beginning on page C-133 provides closeout and cleanup procedures. We assume that the requirements of this section only apply to facilities installed by the contractor under this contract. Is that assumption correct?	Yes	11/23/2010	JBR	No	
14	11/23/2010	Jeff Bean	e-mail	Q&D	Is the intent of section 2550 subsection C3.05 on page C-197 for the contractor to provide a full time individual (24 hours per day, 7 days per week) to the operation and maintenance of the bypass pumping system? If so, does that person have to be onsite at all times? Section 3.02B states that the contractor will have a "qualified attendant available" 24 hours per day seven days per week and further states that the person should be in cellular phone contact with the engineer and the general contractor in the event of emergencies. Please clarify.	Per Section 02550, Part 1.01 C, the contractor is responsible for operating and maintaining temporary bypass pumping, as such, a qualified attendant must be available to respond throughout the duration of the temporary bypass pumping (24 hours per day, 7 days per week)	11/23/2010	JBR	No	
15	11/23/2010	Jeff Bean	e-mail	Q&D	Section 7190 discusses water repellents. Where is the water repellent intended to be applied?	Applied to block wall on sheet C-5	11/23/2010	JBR	No	
16	11/23/2010	Jeff Bean	e-mail	Q&D	Section 1140 page C-19 subsection 1.08A directs the reader to section 02250 for bypass pumping. Section 2250 is not included in the specifications, please clarify.	Will be clarified by addendum	11/23/2010	JBR	Yes	No. 2