

**CARSON CITY PURCHASING AND CONTRACTS**  
**201 North Carson Street, Suite 3**  
**Carson City, NV 89701**  
**775-283-7137/FAX 887-2107**  
**<http://www.carson.org/index.aspx?page=998>**

**NOTICE TO CONTRACTORS**  
**RFP #1213-193**  
**Carson City Foreman Roberts Carriage House**  
**PWP# CC-2013-284**

July 10th, 2013

Addendum No. 1

Please make the following additions/changes to the above referenced project.

1. All exterior trim around windows, doors, and corners to be 2x primed MDF as stated on sheet A7 (the note stating trim around window to be wood in detail 3, sheet A4 is to be removed.) The fascia is also to be primed MDF. Size of trim members to be as shown on the plans.
2. Site demolition work required within 5' of the outside of the Carriage House shall be included in the "Construct Carriage House Cold Shell" bid item. All other site demolition work shall be included under "ADA Site Improvements."

As of July 9, 2013, the following questions and comments have been received. Answers are provided in italics.

1. Does the warm shell option include interior doors, case work, mechanical without commissioning. *The warm shell does not include interior doors, interior case work, or mechanical work.*

**End of Addendum 1**