CARSON CITY PURCHASING AND CONTRACTS 201 North Carson Street, Suite 3 Carson City, NV 89701 775-283-7137/FAX 887-2107 http://www.carson.org/index.aspx?page=998

NOTICE TO CONTRACTORS BID #1314-175 East West Water Transmission Main Project - Ph. 2A-1 PWP # CC-2014-180

May 7, 2014

Addendum No. 3

Please make the following additions/changes/clarifications to the above referenced project:

- 1. The following are based on Request For Information items received by May 6, 2014:
- 1. On East Washington Street the new 24" water pipe is right next to the new curb and stamp colored concrete. The trench will take out the new curb and damage the stamped concrete, are we to account for the removal and replacement of this concrete in our pipe item or can a bid item be added for removal and replacement of stamped concrete and more footage added for the curb & gutter?

The cost of the curb and stamped concrete is to be included in the cost of the pipe.

2. The temporary rip/rap that goes into Ash Creek Channel – is the rip/rap for the entire section or just the trench width?

The temporary rip-rap is just for the trench width.

3. The swing gate the gets removed and replaced which bid item is that supposed to go into?

The relocation of the swing gate is included in the other items of work.

End of Addendum 3