

CARSON CITY PURCHASING AND CONTRACTS

201 North Carson Street, Suite 3

Carson City, NV 89701

775-283-7137/FAX887-2107

<http://www.carson.org/index.aspx?page=998>

NOTICE TO CONTRACTORS

BID #1415-164

W. Washington St. Stormdrain Improvements

PWP # CC-2015-170

Addendum No. 2

Please make the following clarifications to the above referenced project:

1. The City will be furnishing materials per GC.3.7 as listed in the Special Conditions page SC-3

The City will furnish 1200 lineal feet of 42" Spiral Ribbed Pipe, 16 gauge, 56 annular band couplers with neoprene gaskets, one 48"-43" galvanized reducer pipe and 80 lineal feet of 18" HDPE bell & spigot pipe at the City's Corporation Yard. The contractor shall transport material from the City's yard to the job site as needed during the course of construction.

These materials are for bid items BP.3 42" Diameter Spiral Rib Steel Pipe (16ga) (SC 6.1.4) and BP.4 18" HDPE Stormdrain Pipe (SC 6.1.5)

End Addendum