



NOTES:

1. A 3 INCH METER SET REQUIRES A 4 INCH MINIMUM GATE VALVE AT THE MAIN AND A 4 INCH MINIMUM SUPPLY LINE.
2. 3 INCH METER SETS USE 1-1/2 INCH BY-PASS. 4 INCH METER SETS USE 2 INCH BY-PASS.
3. BLUE TRACER WIRE (SEE DWG. C-1.2.1) SHALL BE TAPED EVERY 5 FEET TO PIPE; EXTEND FROM MAIN TO A MINIMUM OF 48 INCHES INTO BOX.
4. PROVIDE CHRISTY B52 BOX WITH M3 LID. WHEN A LOCATION OUTSIDE OF PAVEMENT IS NOT POSSIBLE PROVIDE AN H20 TRAFFIC RATED BOX WITH AN H20 TRAFFIC RATED READING LID.
5. STEEL PIPE SHALL BE PRIMED AND WRAPPED, MIN 10 MILS (CONFORMING TO SSPWC SECTION 203.07.04)
6. STRAINER, SWING CHECK VALVE AND ALL GATE VALVES (EXCEPT GATE VALVE AT MAIN) SHALL BE FLGxFLG, F.C.A's SHALL BE RESTRAINING TYPE, ROMAC OR APPROVED EQUAL. ALL NUTS, BOLTS & WASHERS SHALL BE TYPE 18-8 STAINLESS STEEL (304 OR 304L).

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	REM CHK VLV	9/17	<h2 style="margin: 0;">3" AND 4"</h2> <h1 style="margin: 0;">SERVICE & METER SET</h1>	CARSON CITY
				DRAWING NO. C-3.2.6 (203, 307)
				DATE SEP 2017
APPROVED BY:				