

STAFF REPORT FOR PLANNING COMMISSION MEETING OF SEPTEMBER 30, 2020

FILE NO: LU-2020-0023 & VAR-2020-0003

AGENDA ITEM: E.3 & E.4

STAFF AUTHOR: Hope Sullivan, Planning Manager

AGENDA TITLE: For Possible Action: Discussion and possible action regarding a request for a Special Use Permit to modify a municipal well site by adding an emergency backup generator on property zoned Single Family 21,000 Planned Unit Development (SF21-P), located at 4669 East 5th Street, APN 010-384-08.

For Possible Action: Discussion and possible action regarding a request for a Major Variance for a front setback of 5 feet where a 20 foot front setback is required so as to accommodate an emergency backup generator on property zoned Single Family 21,000 Planned Unit Development (SF21-P), located at 4669 East 5th Street, APN 010-384-08.


STAFF SUMMARY: Carson City Public Works is proposing to install an emergency backup generator at the City's 3600 square feet, 60-foot-deep well site. An existing masonry building on site currently houses the well equipment. The proposed improvements include installing a new generator and fuel tank on a concrete pad. The generator would be approximately 8-feet, 10-inches tall by 6-feet, 8-inches wide by 18-feet, 7-inches long. The generator will be housed inside a white, sound attenuating enclosure. The proposed generator will provide emergency backup power to the well as well as the Riverview Sewer Lift Station. The Planning Commission is authorized to approve a Special Use Permit.

RECOMMENDED MOTIONS:

I move to approve LU-2020-0023, based on the ability to make the required findings and subject to the conditions of approval contained in the staff report.

I move to approve VAR-2020-0003 based on the ability to make the required findings and subject to the conditions of approval contained in the staff report.

VICINITY MAP:



RECOMMENDED SPECIAL USE PERMIT CONDITIONS OF APPROVAL:

1. All development shall be substantially in accordance with the approved site plan.
2. All on and off-site improvements shall conform to City standards and requirements.
3. The use for which this permit is approved shall commence within twelve (12) months of the date of final approval. A single, one (1) year extension of time must be requested in writing to the Planning and Community Development Department thirty (30) days prior to the one (1) year expiration date. Should this permit not be initiated within one (1) year and no extension granted, the permit shall become null and void.
4. The applicant must sign and return the Notice of Decision for conditions of approval within ten (10) days of receipt of notification. If the Notice of Decision is not signed and returned within ten (10) days, then the item may be rescheduled for the next Planning Commission meeting for further consideration.
5. The applicant shall submit exterior light fixture details for any proposed fixtures with the building permit application. Lights must be shielded with a 90-degree full cutoff so that light is projected downward and not horizontally or upward. Light sources or refractors shall not extend below the bottom of the shield.
6. Scheduled testing of the generator shall be scheduled for mid-afternoon on a weekday so as to blend with ambient noise.

RECOMMENDED VARIANCE CONDITIONS OF APPROVAL:

1. All development shall be substantially in accordance with the approved site plan.
2. All on and off-site improvements shall conform to City standards and requirements.
3. The use for which this permit is approved shall commence within twelve (12) months of the date of final approval. A single, one (1) year extension of time must be requested in writing to the Planning and Community Development Department thirty (30) days prior to the one (1) year expiration date. Should this permit not be initiated within one (1) year and no extension granted, the permit shall become null and void.
4. The applicant must sign and return the Notice of Decision for conditions of approval within ten (10) days of receipt of notification. If the Notice of Decision is not signed and returned within ten (10) days, then the item may be rescheduled for the next Planning Commission meeting for further consideration.
5. Scheduled testing of the generator shall be scheduled for mid-afternoon on a weekday so as to blend with ambient noise.

LEGAL REQUIREMENTS: Carson City Municipal Code 18.04.060 Single Family 21,000 (SF21) Conditional Uses

MASTER PLAN DESIGNATION: Low Density Residential

PRESENT ZONING: Single Family 21,000 Planned Unit Development (SF21-P)

KEY ISSUES: Will the use be compatible with the surrounding neighborhood and be in keeping with the standards of the Carson City Municipal Code?

SURROUNDING ZONING AND LAND USE INFORMATION:

NORTH: Single Family 21,000 Planned Unit Development / Single Family Residential
SOUTH: Single Family 21,000 Planned Unit Development / Single Family Residential
EAST: Single Family 21,000 Planned Unit Development / Single Family Residential
WEST: Single Family 21,000 Planned Unit Development / Single Family Residential

ENVIRONMENTAL INFORMATION:

FLOOD ZONE: Zone X Shaded
EARTHQUAKE FAULT: Within 200 feet
EARTHQUAKE POTENTIAL: Greatest Severity
SLOPE/DRAINAGE: Flat

SITE DEVELOPMENT INFORMATION:

LOT SIZE: .54 acres
LEASE AREA: 3600 square feet
EXISTING LAND USE: Single Family Home with a municipal well

PREVIOUS REVIEWS:

None

DISCUSSION:

Per CCMC 18.04.060, a municipal well facility is a conditional use in the SF21-P zoning district and may only be established with a Special Use Permit. The municipal well use is established. The applicant is now seeking to add an emergency generator to the site. The generator will be 18 feet, 7-inches long by 6-feet, 8-inches wide by 8-feet, 10-inches tall. The addition of the generator requires a modification to the special use permit. The Planning Commission is authorized to approve a modification to a special use permit.

The SF21-P zoning district requires a 20-foot front setback. The applicant is proposing a 5-foot front setback. Due to access, the generator must be oriented as proposed.

Of note, on August 17, 2017, the Board of Supervisors voted 5 – 0 to submit a grant application to the Nevada Division of Emergency Management for emergency generators and booster pumps as part of the hazard mitigation grant program. The scope of the grant application, as approved by the Board Supervisors, was for the purchase and installation of four emergency generators in order to provide backup power to critical well facilities and one lift station. The locations where the generators are proposed are:

1881 Winnie Lane
4675 East Fifth Street
603 Marsh Road
2201 West College Parkway

The Planning Commission approved the special use permit for the generator on Winnie Lane at its July 2020 meeting. In addition to the subject request, the requests for the generators on East West College Parkway and Marsh Road are on the Commission's September 2020 agenda for consideration.

The facilities where the generators are proposed were determined based on an analysis of the potential damages for loss of water service. A power outage at the subject well 24 would impact water service to 28,701 people as well as businesses.

The well site is located on an approximately 3600 square foot easement area (approximately 60 feet by 60 feet). Two small buildings on are the easement, one houses the well and one houses the equipment. The parent lot is .54 acres and has a home on it. The well site is in the front of the lot, visible from the road.

PUBLIC COMMENTS:

Public notices were mailed to 40 property owners within 300 feet of the subject site on September 17, 2020. As of the writing of this report, staff has not received any written comments. Any comments that are received after this report is completed will be submitted to the Planning Commission prior to or at the meeting on September 30, 2020 depending on the date of submission of the comments to the Planning Division.

OTHER CITY DEPARTMENTS OR OUTSIDE AGENCY COMMENTS:

Plans were routed to commenting agencies, and the following comments were received. Comments have been incorporated into the conditions of approval, as appropriate.

Engineering Division

The Engineering Division has reviewed the application within our areas of purview relative to adopted standards and practices and to the provisions of CCMC 18.02.080, Conditional Uses. The Engineering Division offers the following discussion:

C.C.M.C. 18.02.080 (5a) - Master Plan

The request is not in conflict with any Engineering Master Plans.

C.C.M.C. 18.02.080 (5b) – Use, Peaceful Enjoyment, Economic Value, Compatibility Development Engineering has no comment on this finding.

C.C.M.C. 18.02.080 (5c) - Traffic/Pedestrians

The use has no impact on vehicle or pedestrian traffic.

C.C.M.C. 18.02.080 (5d) - Public Services

The use improves the reliability of the City's water system.

C.C.M.C. 18.02.080 (5e) – Title 18 Standards

Development Engineering has no comment on this finding.

C.C.M.C. 18.02.080 (5f) – Public health, Safety, Convenience, and Welfare

The project meets engineering standards for health and safety.

C.C.M.C. 18.02.080 (5g) – Material Damage or Prejudice to Other Property

Development Engineering has no comment on this finding.

C.C.M.C. 18.02.080 (5h) – Adequate Information

The plans and reports provided were adequate for this analysis.

Fire Department

Project must comply with the International Fire Code and northern Nevada fire code amendments as adopted by Carson City.

SPECIAL USE PERMIT FINDINGS: Staff's recommendation is based upon the findings as required by CCMC Section 18.02.062 (Special Use Permits) enumerated below and substantiated in the public record for the project.

1. Will be consistent with the master plan elements.

The Water System Master Plan is an integrated planning document that describes existing regulation and legal commitments, water rights, supply sources, storage and distribution infrastructure and characterization of water use. The generator will allow for the distribution of water consistent with the Master Plan during power outages.

2. Will not be detrimental to the use, peaceful enjoyment, economic value, or development of surrounding properties or the general neighborhood; and will cause no objectionable noise, vibrations, fumes, odors, dust, glare or physical activity.

The well site is located in the northeast corner of the subject property. The site is surrounded by single family residential properties ranging from approximately a third of an acre to approximately a half acre. As part of the operations, the generator will be tested weekly for approximately 30 minutes. At 23 feet away from the source, the decibel level will be 70 decibels. This is essentially the sound of a normal conversation. Given that the generator will be in the middle of a residential neighborhood, staff recommends a condition of approval that testing be scheduled for a weekday mid-afternoon. This would coincide with a time when ambient noise may be greater than in the morning or evening, thus causing any noise from testing to blend in with the background noise.

3. Will have little or no detrimental effect on vehicular or pedestrian traffic.

The addition of a generator to the site will not create a detrimental effect on vehicular or pedestrian traffic. There will be no change to traffic patterns.

4. Will not overburden existing public services and facilities, including schools, police and fire protection, water, sanitary sewer, public roads, storm drainage, and other public improvements.

The addition of an emergency generator will not overburden, or even create a demand on public services or facilities. It will allow for more reliable water delivery during times of power outages.

5. Meets the definition and specific standards set forth elsewhere in this title for such particular use and meets the purpose statement of that district.

The subject property is zoned for SF21-P. This zoning district is primarily for single family residences and parks. A municipal well facility is a conditional use in the SF21-P zoning district. The 3600 square foot municipal well site was established with the original Riverview Terrace planned unit development.

The proposed generator will encroach into the required front setback. The applicant is seeking a variance to allow for the encroachment. Provided that applicant can obtain a variance, the request

will be consistent with the purpose statement and standards for the zoning district.

6. The use will not be detrimental to the public health, safety, convenience and welfare.

The emergency generator will not be detrimental to public health, safety, convenience and welfare. Rather, the proposed generator will promote public health and safety by ensuring the availability of water during electricity outages.

7. Will not result in material damage or prejudice to other property in the vicinity.

The proposed emergency generator, subject to the conditions of approval, will not result in material damage or prejudice to other property in the vicinity. As noted, staff was concerned with noise impacts. But with a condition limiting scheduled testing to mid-afternoon on a weekday, staff finds there will not be material damage.

VARIANCE FINDINGS: Staff's recommendation is based upon the findings as required by CCMC Section 18.02.085 (Variance) enumerated below and substantiated in the public record for the project.

- 1. That because of special circumstances applicable to the subject property, including shape, size, topography or location of surroundings, the strict application of the zoning ordinance would deprive the subject property of privileges enjoyed by other properties in the vicinity or under identical zone classification;**

The subject easement that houses the municipal well and associated equipment is approximately 3600 square feet. The setbacks in the SF21-P zoning district presume a lot area of 21,000 square feet. Therefore, the land area where the improvement is contemplated is essentially 17 percent of the minimum lot size for the zoning district. Additionally, the easement area is already improved with one building housing the well, and another building housing the equipment. This creates a constraint as well as the size of the easement.

- 2. That the granting of the application is necessary for the preservation and enjoyment of substantial property rights of the applicant;**

The application is responsible for the provision of water to protect public health and safety. In the case of a power outage, the provision of water to 28,701 people plus businesses may be threatened, thus sacrificing health and safety. The applicant is seeking to install as generator to improve the reliability of the water system, consistent with its responsibility.

The applicant is also responsible for the provision of wastewater collection and treatment. As such, per the State law, the applicant must provide backup power at all sanitary sewer lift station facilities and water pumping facilities. The placement of the generator at the Well 24 site will allow for the removal of the existing Riverview Lift Station generator, currently located in the median in East Fifth Street, and is at the end of its useful life.

- 3. That the granting of the application will not, under the circumstances of the particular case, adversely affect to a material degree the health or safety of persons residing or working in the neighborhood of the subject property and will not be materially detrimental to the public welfare or materially injurious to property or improvements in the neighborhood of the subject property.**

The well site is located in the northeast corner of the subject property. The site is surrounded by single family residential properties ranging from approximately a third of an acre to approximately a half acre. As part of the operations, the generator will be tested weekly for approximately 30 minutes. At 23 feet away from the source, the decibel level will be 70 decibels. This is essentially the sound of a normal conversation. Given that the generator will be in the middle of a residential neighborhood, staff recommends a condition of approval that testing be scheduled for a weekday mid-afternoon. This would coincide with a time when ambient noise may be greater than in the morning or evening, thus causing any noise from testing to blend in with the background noise.

Attachments:

LU-2020-0023 application

VAR-2020-0003 application



CARSON CITY NEVADA
Consolidated Municipality and State Capital
PUBLIC WORKS

July 15th, 2020

Carson City Planning Commission
108 E. Proctor Street
Carson City, Nevada 89701

RE: Special Use Permit Project Description – Carson City Municipal Well 24

Carson City Public Works is proposing to install a diesel generator at the City's Municipal Well 24 site. The improvements would include installing a new generator and fuel tank on a concrete pad in the location indicated on the site map. The generator would be approximately 8'-10" tall, 6'-8" wide, and 18'-7" long. Pipe bollards are to be placed on the driveway side of the generator and existing landscaping is to be repaired. The generator will be housed inside a white, level 2, sound attenuating enclosure. The proposed generator will provide emergency backup power to Well 24 as well as the Riverview Sewer Lift Station.

Carson City has received a grant through the Nevada Department of Emergency Management (NDEM) which funds the installation of emergency generators at four critical well facilities in the City. Well 24 was identified as one of the critical facilities and has the potential to impact 28,000 people in the event of a power outage. Installation of the portable generator will provide resiliency against outages and better service to the residents of Carson City.

Additionally, the generator at Well 24 will provide emergency backup power for Riverview Lift Station. The lift station currently has a diesel generator located in the median directly adjacent to the lift station. The existing generator is at the end of its useful life and will be removed as a part of the Riverview Lift Station Upgrades Project planned to be constructed in the fall of 2020. Due to the need to provide redundant power to the lift station, the City plans to connect the Riverview Lift Station to the new generator at Well 24.

If you have any questions, please feel free to call or email me.

Sincerely,

Darren Anderson, P.E.
Project Manager
Carson City Public Works
danderson@carson.org

Carson City Planning Division
108 E. Proctor Street • Carson City NV 89701
Phone: (775) 887-2180 • E-mail: planning@carson.org

FOR OFFICE USE ONLY:

CCMC 18.02.080

SPECIAL USE PERMIT

FEE*: \$2,450.00 MAJOR
\$2,200.00 MINOR (Residential zoning districts)
+ noticing fee

*Due after application is deemed complete by staff

SUBMITTAL PACKET – 4 Complete Packets (1 Unbound Original and 3 Copies) including:

- Application Form
- Detailed Written Project Description
- Site Plan
- Building Elevation Drawings and Floor Plans
- Special Use Permit Findings
- Master Plan Policy Checklist
- Applicant's Acknowledgment Statement
- Documentation of Taxes Paid-to-Date
- Project Impact Reports (Engineering)

CD or USB DRIVE with complete application in PDF

Application Received and Reviewed By: _____

Submittal Deadline: Planning Commission application submittal schedule.

Note: Submittals must be of sufficient clarity and detail for all departments to adequately review the request. Additional information may be required.

FILE # LU-2020-0023

APPLICANT Carson City Public Works PHONE # 283-7584

MAILING ADDRESS, CITY, STATE, ZIP
3505 Butti Way, Carson City, NV, 89701

EMAIL ADDRESS
danderson@carson.org

PROPERTY OWNER Carson City PHONE # 887-2000

MAILING ADDRESS, CITY, STATE, ZIP
201 N. Carson St., Carson City, NV, 89701

EMAIL ADDRESS
danderson@carson.org 283-7584

APPLICANT AGENT/REPRESENTATIVE Darren Anderson PHONE # 283-7584

MAILING ADDRESS, CITY STATE, ZIP
3505 Butti Way, Carson City, NV, 89701

EMAIL ADDRESS
danderson@carson.org

Project's Assessor Parcel Number(s): 01038499 Street Address 4675 East Fifth Street

Project's Master Plan Designation Low Density Residential Project's Current Zoning SF21P Nearest Major Cross Street(s) Well Way

Please provide a brief description of your proposed project and/or proposed use below. Provide additional pages to describe your request in more detail. Carson City Public Works is proposing to place an emergency backup generator at the City's Well 24 site. The City received a FEMA grant to place emergency generators at 4 critical well sites which including Well 24.

PROPERTY OWNER'S AFFIDAVIT

I, Daniel Stucky, being duly deposed, do hereby affirm that I am the record owner of the subject property, and that I have knowledge of, and I agree to, the filing of this application.


Signature [Signature] Address 3505 Butti Way Date 7/21/2020

Use additional page(s) if necessary for additional owners.

STATE OF NEVADA
COUNTY)

On July 21, 2020, Dan Stucky, personally appeared before me, a notary public, personally known (or proved) to me to be the person whose name is subscribed to the foregoing document and who acknowledged to me that he/she executed the foregoing document.

Lena E. Reseck
Notary Public



NOTE: If your project is located within the Historic District or airport area, it may need to be scheduled before the Historic Resources Commission or the Airport Authority in addition to being scheduled for review by the Planning Commission. Planning staff can help you make this determination.

STATEMENT OF FINDINGS
APPLICATION FOR SPECIAL USE PERMIT
WELL 24 EMERGENCY GENERATOR PROJECT

Question 1: Will be consistent with the objectives of the Master Plan elements.

Installation of the emergency backup generator at Well 24 will be in accordance with Carson City Master Plan. A backup generator program was identified in the 2015 Water Master Plan Update.

The generator will be constructed of long lasting, rust resistant materials and be housed in a neutral colored, level 2, sound attenuating enclosure.

The generator at Well 24 will provide emergency backup power for Riverview Sewer Lift Station which is located in the median of Fifth Street, 500 feet to the east. Riverview Lift Station handles all sanitary sewer flow in the area of the Riverview Estates Subdivision. Backup power for the sewer lift station is critical since it is a state permitting requirement for this type of facility and is necessary in order to ensure that no spills occur in the event of a power outage. Completion of the project will also assist the City in its efforts to continue to provide a reliable supply of water to those connected to the City's water system in turn helping to maintain good quality of life for residents. Installation of the emergency backup generator will help sustainability of our community by adding resiliency to the City's water system.

Question 2: Will not be detrimental to the use, peaceful enjoyment, economic value, or development of surrounding properties or the general neighborhood; and is compatible with and preserves the character and integrity of adjacent development and neighborhood or includes improvements or modifications either on-site or within the public right-of-way to mitigate development related to adverse impacts such as noise vibrations, fumes, odors, dust, glare or physical activity.

Well 24 is one of several wells serving much of the central and eastern areas of the City. Installation of the emergency generator will help provide water to citizens during power outages.

The generator will operate during power outages if the well is in operation at the time of the outage. The generator will also operate on a scheduled maintenance startup frequency of once a week for 30 minutes. The maintenance startup will be scheduled during daytime weekday hours to minimize disturbance to neighbors.

As a separate phase of the improvements to be completed which are associated with the emergency generator at the Well 24 Site; the City plans to remove the existing generator at the Riverview Lift Station site which is at the end of its useful life. The current generator at Riverview Lift Station is located in the center median of Fifth street, visible to many residents, and has very poor sound attenuation. By removing the generator and re-feeding the power service to the Riverview Lift Station from the Well 24 Site, the Lift Station will be supported by the new generator at the well site. The new generator will be

less visible to residents in the area, have far better sound attenuation, and be more protected against damage by vehicles.

In summary, the new emergency generator will help to provide necessary backup for water and sewer utilities to the residents in the area as well as limit visual impact of the backup facility by relocating it from the center median of Fifth Street to the Well 24 property.

Adjacent properties:

Single Family-21,000 square feet (SF21) in all directions

Question 3: Will have little or no detrimental effect on vehicular traffic or pedestrian traffic.

The project will have no effect on vehicular or pedestrian traffic.

Question 4: Will not overburden existing public services and facilities, including schools, police and fire protection, water, sanitary sewer, public roads, storm drainage and other public improvements.

The project will help improve the public water system and service. Installation of an emergency generator at Well 24 will provide increased reliability of the water system.

Question 5: Meets the definition and specific standards set forth elsewhere in Carson City Municipal Code, Title 18 for such particular use and meets the purpose statement of that district.

The proposed improvements will help the City to continue to use the site as a municipal well facility. The existing uses on City controlled facilities in the area will not change as a result of this project.

Question 6: Will not be detrimental to the public health, safety, convenience and welfare.

This project will help to improve public health, safety, convenience and welfare by adding resiliency to the Riverview Lift Station in addition to Well 24 providing improved reliability of water and sewer services for residents in the area.


Question 7: Will not result in material damage or prejudice to other property in the vicinity, as a result of proposed mitigation measures.

The use of the land will not vary from how it has been previously used. The site will continue to be used as a municipal well facility with the proposed improvements. While some landscaping will need to be

removed to accommodate the footprint of the generator, all other landscaping will remain in place. The well will operate during power outages if the well is in operation at the time of the outage and on a scheduled maintenance startup frequency of once a week for 30 minutes. The maintenance startup will be scheduled during daytime weekday hours to minimize disturbance to neighbors.

ACKNOWLEDGMENT OF APPLICANT

I certify that the forgoing statements are true and correct to the best of my knowledge and belief. I agree to fully comply with all conditions as established by the Planning Commission. I am aware that this permit becomes null and void if the use is not initiated within one-year of the date of the Planning Commission's approval; and I understand that this permit may be revoked for violation of any of the conditions of approval. I further understand that approval of this application does not exempt me from all City code requirements.



Darren Anderson

07/27/2020

Applicant's Signature

Print Name

Date


Carson City Planning Division 108 E. Proctor Street • Carson City NV 89701 Phone: (775) 887-2180 • E-mail: planning@carson.org		FOR OFFICE USE ONLY: CCMC 18.02.085	
FILE # <i>VAR-2020-0003</i>		MAJOR VARIANCE	
APPLICANT Carson City Public Works	PHONE # 283-7584	FEE*: \$2,150.00 + noticing fee *Due after application is deemed complete by staff	
MAILING ADDRESS, CITY, STATE, ZIP 3505 Butti Way, Carson City, NV, 89701		<input type="checkbox"/> SUBMITTAL PACKET – 4 Complete Packets (1 Unbound Original and 3 Copies)	
EMAIL ADDRESS danderson@carson.org		<input type="checkbox"/> Application Form <input type="checkbox"/> Detailed Written Project Description <input type="checkbox"/> Site Plan <input type="checkbox"/> Building Elevation Drawings and Floor Plans <input type="checkbox"/> Variance Findings <input type="checkbox"/> Applicant's Acknowledgment Statement <input type="checkbox"/> Documentation of Taxes Paid-to-Date	
PROPERTY OWNER Carson City	PHONE # 887-2000	<input type="checkbox"/> CD or USB DRIVE with complete application in PDF	
MAILING ADDRESS, CITY, STATE, ZIP 201 N. Carson St., Carson City, NV, 89701		Application Reviewed and Received By: <hr/>	
EMAIL ADDRESS danderson@carson.org		Submission Deadline: Planning Commission application submittal <u>schedule</u> .	
APPLICANT AGENT/REPRESENTATIVE Darren Anderson	PHONE # 283-7584	Note: Submittals must be of sufficient clarity and detail such that all departments are able to determine if they can support the request. Additional information may be required.	
MAILING ADDRESS, CITY, STATE, ZIP 3505 Butti Way, Carson City, NV, 89701			
EMAIL ADDRESS danderson@carson.org			
Project's Assessor Parcel Number(s): 01038499		Street Address 4675 East Fifth Street	
Project's Master Plan Designation Low Density Residential	Project's Current Zoning SF21P	Nearest Major Cross Street(s) Well Way	

Please provide a brief description of your proposed project below. Provide additional pages to describe your request in more detail.

Carson City Public Works is proposing to place an emergency backup generator at the City's Well 24 site. The City received a FEMA grant to place emergency generators at 4 critical well sites which includes Well 24.

PROPERTY OWNER'S AFFIDAVIT

I, Daniel Stucky, being duly deposed, do hereby affirm that I am the record owner of the subject property, and that I have knowledge of, and I agree to, the filing of this application.

Signature:  Address: 3505 Butti Way, Carson City, NV 89701 Date: 8/27/20

Use additional page(s) if necessary for other names.

STATE OF NEVADA)
 COUNTY)

On _____, 20____, _____, personally appeared before me, a notary public, personally known (or proved) to me to be the person whose name is subscribed to the foregoing document and who acknowledged to me that he/she executed the foregoing document.

 Notary Public

NOTE: If your project is located within the Historic District or airport area, it may need to be scheduled before the Historic Resources Commission or the Airport Authority in addition to being scheduled for review by the Planning Commission. Planning staff can help you make this determination.

STATEMENT OF FINDINGS

APPLICATION FOR MAJOR VARIANCE

WELL 24 EMERGENCY GENERATOR PROJECT

Question 1: That because of special circumstances to the subject property, including shape, size, topography or location of surroundings, the strict application of the zoning ordinance would deprive the subject property of privileges enjoyed by other properties in the vicinity or under identical zone classifications.

The subject property was granted as an easement to the City in order to construct a well. The size of the property was determined in order to house the well facility and equipment with minimal additional space in order to limit the impact to the adjacent property that the easement was granted from. Due to the limited space within the easement area, the City is proposing to install the generator towards the front of the property, encroaching the minimum front setback of 20'.

There are 3 areas within the property that have enough space for the generator. The City considered the different locations before determining the location shown as the best location. The two other locations considered were the space in the southwest corner of the property and space along the eastern fence of the property. The southwest corner of the property would require the generator to be placed on top of critical underground components of the well. Additionally, access for placement of the generator and any extensive repair and maintenance would need to be from the adjacent property owner's driveway. The location along the eastern fence does not allow for adequate room to open the generator doors and effectively perform repair and maintenance, and would encroach on the side property setback.

Part of the City's 2015 Water Master Plan Update includes a backup generator program which is necessary to provide reliable service to residents and businesses throughout the City. Well 24 was selected as one of the most critical sites to maintain power during a power outage and in order to provide a satisfactory level of service to water users.

Question 2: That the granting of the application is necessary for the preservation and enjoyment of substantial property rights of the applicant.

The City obtained the easement for the sole purpose of operating a well. Allowing the placement and installation of the emergency backup generator will allow the City to continue to use the property for the purpose it was originally acquired. The City is proposing to install the generator in order to meet State regulations which require standby power to be provided for pumping facilities.

Question 3: That granting of the application will not, under the circumstances of the particular case, adversely affect to a material degree the health or safety of persons residing or working in the neighborhood of the subject property and will not be materially detrimental to the public welfare or materially injurious to property or improvements in the neighborhood of the subject property.

Well 24 is one of several wells serving much of the central and eastern areas of the City. Installation of the emergency generator will help maintain supply and pressure of water to citizens during power outages and help to avoid material or adverse effects that could be caused in the neighborhood if backup power were not provided.

As a separate phase of the improvements to be completed which are associated with the emergency generator at the Well 24 Site; the City plans to remove the existing generator at the Riverview Lift Station site which is at the end of its useful life. The current generator at Riverview Lift Station is located in the center median of Fifth street, visible to many residents, and has very poor sound attenuation. By removing the generator and re-feeding the power service to the Riverview Lift Station from the Well 24 Site, the Lift Station will be supported by the new generator at the well site. The new generator will be less visible to residents in the area, have far better sound attenuation, and be more protected against damage by vehicles.

State regulations require the City to provide backup power at all sanitary sewer lift station facilities and water pumping facilities. Adding the generator at the Well 24 site will allow the City to meet this requirement, protect the environment, and provide resiliency to both the sanitary sewer and water systems.

The generator will operate during power outages if the well is in operation at the time of the outage. The generator will also operate on a scheduled maintenance startup frequency of once a week for 30 minutes. The maintenance startup will be scheduled during daytime weekday hours to minimize disturbance to neighbors.

ACKNOWLEDGMENT OF APPLICANT

I certify that the forgoing statements are true and correct to the best of my knowledge and belief. I agree to fully comply with all conditions as established by the Planning Commission. I am aware that this permit becomes null and void if the use is not initiated within one-year of the date of the Planning Commission's approval; and I understand that this permit may be revoked for violation of any of the conditions of approval. I further understand that approval of this application does not exempt me from all City code requirements.



Darren Anderson

8/28/2020

Applicant's Signature

Print Name

Date

Master Plan Policy Checklist

Special Use Permits & Major Project Reviews & Administrative Permits

PURPOSE

The purpose of a development checklist is to provide a list of questions that address whether a development proposal is in conformance with the goals and objectives of the 2006 Carson City Master Plan that are related to non-residential and multi-family residential development. This checklist is designed for developers, staff, and decision-makers and is intended to be used as a guide only.

Development Name: _____

Reviewed By: _____

Date of Review: _____

DEVELOPMENT CHECKLIST

The following five themes are those themes that appear in the Carson City Master Plan and which reflect the community's vision at a broad policy level. Each theme looks at how a proposed development can help achieve the goals of the Carson City Master Plan. A check mark indicates that the proposed development meets the applicable Master Plan policy. The Policy Number is indicated at the end of each policy statement summary. Refer to the Comprehensive Master Plan for complete policy language.

CHAPTER 3: A BALANCED LAND USE PATTERN



The Carson City Master Plan seeks to establish a balance of land uses within the community by providing employment opportunities, a diverse choice of housing, recreational opportunities, and retail services.

Is or does the proposed development:

- Meet the provisions of the Growth Management Ordinance (1.1d, Municipal Code 18.12)?
- Use sustainable building materials and construction techniques to promote water and energy conservation (1.1e, f)?
- Located in a priority infill development area (1.2a)?
- Provide pathway connections and easements consistent with the adopted Unified Pathways Master Plan and maintain access to adjacent public lands (1.4a)?

- Protect existing site features, as appropriate, including mature trees or other character-defining features (1.4c)?
- At adjacent county boundaries or adjacent to public lands, coordinated with the applicable agency with regards to compatibility, access and amenities (1.5a, b)?
- In identified Mixed-Use areas, promote mixed-use development patterns as appropriate for the surrounding context consistent with the land use descriptions of the applicable Mixed-Use designation, and meet the intent of the Mixed-Use Evaluation Criteria (2.1b, 2.2b, 2.3b, Land Use Districts, Appendix C)?
- Meet adopted standards (e.g. setbacks) for transitions between non-residential and residential zoning districts (2.1d)?
- Protect environmentally sensitive areas through proper setbacks, dedication, or other mechanisms (3.1b)?
- Sited outside the primary floodplain and away from geologic hazard areas or follows the required setbacks or other mitigation measures (3.3d, e)?
- Provide for levels of services (i.e. water, sewer, road improvements, sidewalks, etc.) consistent with the Land Use designation and adequate for the proposed development (Land Use table descriptions)?
- If located within an identified Specific Plan Area (SPA), meet the applicable policies of that SPA (Land Use Map, Chapter 8)?

CHAPTER 4: EQUITABLE DISTRIBUTION OF RECREATIONAL OPPORTUNITIES



The Carson City Master Plan seeks to continue providing a diverse range of park and recreational opportunities to include facilities and programming for all ages and varying interests to serve both existing and future neighborhoods.

Is or does the proposed development:

- Provide park facilities commensurate with the demand created and consistent with the City's adopted standards (4.1b)?
- Consistent with the Open Space Master Plan and Carson River Master Plan (4.3a)?

CHAPTER 5: ECONOMIC VITALITY



The Carson City Master Plan seeks to maintain its strong diversified economic base by promoting principles which focus on retaining and enhancing the strong employment base, include a broader range of retail services in targeted areas, and include the roles of technology, tourism, recreational amenities, and other economic strengths vital to a successful community.

Is or does the proposed development:

- Encourage a citywide housing mix consistent with the labor force and non-labor force populations (5.1j)
- Encourage the development of regional retail centers (5.2a)
- Encourage reuse or redevelopment of underused retail spaces (5.2b)?
- Support heritage tourism activities, particularly those associated with historic resources, cultural institutions and the State Capitol (5.4a)?
- Promote revitalization of the Downtown core (5.6a)?
- Incorporate additional housing in and around Downtown, including lofts, condominiums, duplexes, live-work units (5.6c)?

CHAPTER 6: LIVABLE NEIGHBORHOODS AND ACTIVITY CENTERS



The Carson City Master Plan seeks to promote safe, attractive and diverse neighborhoods, compact mixed-use activity centers, and a vibrant, pedestrian-friendly Downtown.

Is or does the proposed development:

- Use durable, long-lasting building materials (6.1a)?
- Promote variety and visual interest through the incorporation of varied building styles and colors, garage orientation and other features (6.1b)?
- Provide variety and visual interest through the incorporation of well-articulated building facades, clearly identified entrances and pedestrian connections, landscaping and other features consistent with the Development Standards (6.1c)?
- Provide appropriate height, density and setback transitions and connectivity to surrounding development to ensure compatibility with surrounding development for infill projects or adjacent to existing rural neighborhoods (6.2a, 9.3b 9.4a)?
- If located in an identified Mixed-Use Activity Center area, contain the appropriate mix, size and density of land uses consistent with the Mixed-Use district policies (7.1a, b)?
- If located Downtown:
 - Integrate an appropriate mix and density of uses (8.1a, e)?
 - Include buildings at the appropriate scale for the applicable Downtown Character Area (8.1b)?
 - Incorporate appropriate public spaces, plazas and other amenities (8.1d)?
- Incorporate a mix of housing models and densities appropriate for the project location and size (9.1a)?

CHAPTER 7: A CONNECTED CITY



The Carson City Master Plan seeks promote a sense of community by linking its many neighborhoods, employment areas, activity centers, parks, recreational

amenities and schools with an extensive system of interconnected roadways, multi-use pathways, bicycle facilities, and sidewalks.

Is or does the proposed development:

- Promote transit-supportive development patterns (e.g. mixed-use, pedestrian-oriented, higher density) along major travel corridors to facilitate future transit (11.2b)?
- Maintain and enhance roadway connections and networks consistent with the Transportation Master Plan (11.2c)?
- Provide appropriate pathways through the development and to surrounding lands, including parks and public lands, consistent with the Unified Pathways Master Plan (12.1a, c)?



Image shown might not reflect actual configuration

350 ekW- 400 ekW

60 Hz

Standby	Prime
350 ekW	320 ekW
400 ekW	365 ekW

BENEFITS & FEATURES

CAT® GENERATOR SET PACKAGE

Cat generator set packages have been fully prototype tested and certified torsional vibration analysis reports are available. The packages are designed to meet the NFPA 110 requirement for loading, conform to the ISO 8528-5 steady state and full transient response requirements.

CAT DIESEL ENGINES

The four-cycle Cat diesel engine combines consistent performance with excellent fuel economy and transient response that meets or exceeds ISO 8528-5. The engines feature a reliable, rugged, and durable design that has been field proven in thousands of applications worldwide in emergency standby installations.

COOLING SYSTEM

The cooling system has been designed and tested to ensure proper generator set cooling, and includes the radiator, fan, belts, and all guarding installed as standard. Contact your Cat dealer for specific ambient and altitude capabilities.

GENERATORS

The generators used on Cat packages have been designed and tested to work with the Cat engine. The generators are built with robust Class H insulation and provide industry-leading motor starting capability and altitude capabilities.

EMCP CONTROL PANELS

The EMCP controller features the reliability and durability you have to come to expect from your Cat equipment. The EMCP 4 is a scalable control platform designed to ensure reliable generator set operation, providing extensive information about power output and engine operation. EMCP 4 systems can be further customized to meet your needs through programming and expansion modules.

SPECIFICATIONS

ENGINE SPECIFICATIONS

Engine Model	Cat® C13 ACERT In-line 6, 4-cycle diesel
Bore x Stroke	130mm x 157mm (5.1 in x 6.2 in)
Displacement	12.5 L (763 in ³)
Compression Ratio	16.3:1
Aspiration	Turbocharged Air-to-Air Aftercooled
Fuel Injection System	MEUI
Governor	Electronic ADEM™ A4
Emission Certifications	EPA TIER III

GENERATOR SET SPECIFICATIONS

Alternator Design	Brushless Single Bearing, 4 Pole
Stator	2/3 Pitch
No. of Leads	12
Available Voltage Options	600/480/440/240/220V
Frequency	60Hz
Alternator Voltage	24V
Alternator Insulation & IP	Class H; IP23
Standard Temperature Rise	125/130 Deg C
Available Excitation Options	Self-Excited, PMG
Voltage Regulation, Steady State +/-	≤1%


STANDARD EQUIPMENT

Air inlet system	Aftercooler core. Turbocharger
Control panels	EMCP4.2 control panel.
Cooling system	Coolant drain line with valve; terminated on edge of base. Fan and belt guards. Coolant Level Sensor Thermostats and housing, full open temperature 92 deg C (198 deg F). Coolant level sight gauge. Jacket water pump, gear driven, centrifugal. Caterpillar Extended Life Coolant.
Exhaust system	Exhaust manifold; dry.
Fuel system	Primary fuel filter w/integral water separator & secondary filter. Fuel cooler. Fuel priming pump. Flexible fuel lines. Engine fuel transfer pump
Generators and generator attachments	Brushless, self-excited 2/3 pitch, random wound. IP23 Protection. Insulation Class H and temperature rise Power centre, IP22 bottom cable entry Segregated low voltage wiring pane
Governing system	Cat Electronic Governor (ADEM A4).
Protection System	Safety Shutoff – High Water Temperature Safety Shutoff – Low Oil Pressure Safety Shutoff – Overspeed Coolant Level Sensor
Base / Fuel Tank	Narrow Skid Wide / Standard Sub Tank Base – UL & ULC Listed Integral Tank Base – UL & ULC Listed Spill Containment Overfill Prevention Valve
Starting/charging system	24-Volt Electric Starting Motor Charging Alternator
Certifications	EPA Stationary Emergency Use

OPTIONAL EQUIPMENT

Air inlet system	Single/Dual Element Air Cleaner Heavy Duty Air Cleaner
Control panels	EMCP 4.4 Local Annunciator Remote Annunciators Discrete I/O Module Device Server Volt Free Contact Earth (Ground) Fault Relay
Circuit Breakers	3-Pole 100% Rated – Single (Manual & Motorized). 3-Pole 100% Rated – Dual & Third (Manual). External Paralleling Auxiliary Contacts Neutral Bar
Enclosures	Sound Attenuated (SA). Weather Protective
Cooling system	Stone guards.
Mufflers	Industrial grade (10 dBA) Residential and Critical grade (25 dBA)
Base / Fuel Tank	Audio & Visual Fuel Alarm
Fuel System	Integral 670 Gal Tank Base Sub Tank Bases:660, 1000, 1900, 2200 Gal
Generators and generator attachments	Excitation – Self Excitation – Internal / AREP / PMG Oversize Coastal Protection (CIP) Space Heater Control
Starting/charging system	Standard Battery Set Oversize Battery Set.
Certifications	UL2200 Listed CSA 22.2 Certification of Compliance – IBC Seismic Certification of Compliance – IBC Seismic and OSHPD
General	Tool Set.

WEIGHTS & DIMENSIONS



Standby Ratings	Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Generator Set Weight kg (lb)
350 ekW	3505 (138)	1652 (65)	2069 (82)	3696 (8147)
400 ekW	3505 (138)	1652 (65)	2069 (82)	3823 (8427)



Image shown might not reflect actual configuration

INTEGRAL & SUB BASE FUEL TANKS

FEATURES

- UL Listed for United States (UL 142) and Canada (CAN/ULC S601)
- Facilitates compliance with NFPA 30 code, NFPA 37 and 110 standards and CSA C282 code
- Dual wall
- Lockable fuel fill cap, 4" (101.6 mm) NPT
- Low fuel level warning standard, customer configurable warning or shutdown
- Primary tank leak detection switch in containment basin
- Tank design provides capacity for thermal expansion of fuel
- Fuel supply dip tube is positioned so as not to pick up fuel sediment.
- Fuel return and supply dip tube is separated by an internal baffle to prevent immediate re-supply of heated return fuel
- Pressure washed with an iron phosphate solution
- Interior tank surfaces coated with a solvent-based thin-film rust preventative
- Heavy gauge steel gussets with internal lifting rings
- Primary and secondary tanks are leak tested at 20.7 kPa (3 psi) minimum
- Compatible with open packages and enclosures
- Gloss black polyester alkyd enamel exterior paint
- Welded steel containment basin (minimum of 110% of primary tank capacity)
- Direct reading fuel gauge with variable electrical output
- Emergency vents on primary and secondary tanks are sized in accordance with NFPA 30
- Rear stub-up access

SUB BASE

- The sub-base fuel tank mounts below the generator set wide base

INTEGRAL

- Integral diesel fuel tank is incorporated into the generator set base frame
- Robust base design includes linear vibration isolators between tank base and engine generator.

OPTIONS

- Audio/visual fuel level alarm panel
- 5gal (18.9 L) spill containment
- 5gal (18.9 L) spill containment with fuel fill drop tube with in 6" (152 mm) from bottom of tank
- 5gal (18.9 L) spill containment with overflow prevention valve and fuel fill drop tube with in 6" (152 mm) from bottom of tank
- ULC Listed 7.5gal (28.4 L) spill containment with vent extensions, vent whistle, and drop tube facilitating compliance with CSA B139-09
- ULC Listed 7.5gal (28.4 L) spill containment with overflow prevention valve, vent extensions, vent whistle and drop tube facilitating compliance with CSA B139-09

Integral & Sub-Base Fuel Tank Base Useable Capacities with Fuel Tank Dimensions & Weights

Integral – Width (W) 2014 mm (79.3 in)

Sub-base – Width (W) 2056 mm (81.0 in)

A. Open Set & Weather Protective Enclosure


C13 Tank Design	Feature Code	Total Capacity		Useable Capacity		Tank Only						Overall Package Height with Tank			
						Dry Weight		Height 'H'		Length 'L'		Open		Enclosure	
		Litre	Gallon	litre	Gallon	kg	lb	mm	in	mm	in	mm	in	mm	in
Integral	FTDW013	2646	699	2540	671	1569	3450	762	30	5461	215	2552	100.5	2743	108
Sub-Base	FTDW005	3941	1041	3876	1024	1659	3657	635	25	5550	218.5	2763	108.8	2955	116.3
Sub-Base	FTDW006	7643	2019	7556	1996	2228	4912	889	35	6184	243.5	3017	118.8	3209	126.3
Sub-Base	FTDW007	8339	2203	8244	2178	2150	4134	889	35	7074	278.5	2291	117.8	3789	149.2
Sub-Base	FTDW011	2476	654	2435	643	1468	3236	635	25	3810	150	2763	108.8	2955	116.3

B. Sound Attenuated Enclosure

C13 Tank Design	Feature Code	Total Capacity		Useable Capacity		Tank Only						Overall Package Height with Tank			
						Dry Weight		Height 'H'		Length 'L'		Open		Enclosure	
		litre	Gallon	litre	Gallon	kg	lb	mm	in	mm	in	mm	in	mm	in
Integral	FTDW013	2646	699	2540	671	1569	3450	762	30.0	5461	215.0	NA	NA	2743	108.0
Sub-Base	FTDW005	3941	1041	3876	1024	1659	3657	635	25.0	5550	218.5	NA	NA	2955	116.3
Sub-Base	FTDW006	7643	2019	7556	1996	2033	4483	889	35.0	6184	243.5	NA	NA	3209	126.3
Sub-Base	FTDW007	8339	2203	8244	2178	2292	5052	889	35.0	7074	278.5	NA	NA	3209	126.3
Sub-Base	FTDW011	2476	654	2435	643	1468	3236	635	25.0	3810	150.0	NA	NA	2955	116.3

C. Estimated Run Time (Hours) at 100% Load

C13 Tank Design	Feature Code	Standby Ratings (ekW)		Prime Ratings (ekW)	
		400	350	350	320
Integral Tank	FTDW013	24	27	25	29
Sub-Base	FTDW005	36	41	38	43
Sub-Base	FTDW006	71	80	74	85
Sub-Base	FTDW007	77	87	81	93
Sub-Base	FTDW011	23	25	24	27



The heights listed above do not include lumber used during manufacturing and shipping

Tanks with full electrical stub-up area include removable end channel. Tanks with RH stub-up include stubup area directly below the circuit breaker or power terminal strips. Dimensions include weather-protective enclosure exhaust system.

Dual wall sub-base tanks are UL Listed and constructed in accordance with UL Standard for Safety UL 142, Steel Aboveground Tanks for Flammable and Combustible Liquids and Canada CAN/ULC S601, Standard for Shop Fabricated Steel Aboveground Horizontal Tanks for Flammable and Combustible Liquids.

Fuel tanks and applicable options facilitate compliance with the following United States NFPA Code and Standards:

NFPA 30: Flammable and Combustible Liquids Code

NFPA 37: Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines

NFPA 110: Standard for Emergency and Standby Power Systems

Fuel tanks and applicable options facilitate compliance with the following Canadian Standard and Code:

CSA C282 – Emergency Electrical Power Supply for Buildings

CSA B139-09 – Installation Code for Oil-Burning Equipment

The following sub-base fuel tanks meet Chicago code for containment and labelling:

FTDW005

FTDW008

FTDW011



Image shown might not reflect actual configuration

SOUND ATTENUATED & WEATHER PROTECTIVE ENCLOSURES

60 Hz

FEATURES

Robust / Highly Corrosion Resistant Construction

- Factory installed on skid base
- Environmentally friendly, polyester powder baked paint
- 14 gauge steel
- Interior zinc plated fasteners
- Exterior stainless steel fasteners
- Internally mounted exhaust silencing system
- Designed and tested to comply with UL 2200 Listed generator set package
- Compression door latches providing solid door seal

Excellent Access

- Large cable entry area for installation ease
- Accommodates side mounted single or multiple breakers
- Three doors on both sides
- Vertically hinged allow 180° opening rotation and retention with door stays
- Lube oil and coolant drains piped to the exterior of the enclosure base
- Radiator fill cover

Security and Safety

- Lockable access doors which give full access to control panel and breaker
- Cooling fan and battery charging alternator fully guarded
- Fuel fill, oil fill and battery can only be reached via lockable access
- Externally mounted emergency stop button
- Designed for spreader bar lifting to ensure safety
- Stub-up area is rodent proof

Transportability

- These enclosures are of extremely rugged construction to withstand outdoor exposure and rough handling common on many construction sites.

Options (Sound Attenuated)

- Enclosure constructed with 14 gauge steel
- Enclosure constructed with 12 gauge aluminum (5052 grade)
- Caterpillar yellow or white paint
- Control panel viewing window
- UL Listed integral fuel tank with 670, 400, and 300 gallon capacities
- UL Listed sub base fuel tank with 660, 1000, 1900, and 2200 gallon capacities.
- Seismic certification per applicable building codes: IBC 2000, IBC 2003, IBC 2006, IBC 2009, IBC 2012, CBC 2007, CBC 2010
- IBC Certification for 150 mph wind loading
- AC/DC lighting package
- 5 kW Canopy space heater to facilitate compliance with NFPA 110
- Motorized louvers and gravity discharge damper
- 125A Load Center
- GFCI outlets

Options (Weather Protective)

- Caterpillar Yellow or white paint
- UL Listed integral fuel tank with 680, 400, and 300 gallon capacities
- UL Listed sub-base fuel tank with 660, 1000, 1900, and 2200 gallon capacities.
- Seismic certification per applicable building codes: IBC 2000, IBC 2003, IBC 2006, IBC 2009, IBC 2012, CBC 2007, CBC 2010.
- IBC Certification for 150 mph wind loading
- Anchoring details are site specific and are dependent on many factors such as generator set size, weight, and concrete strength. IBC Certification requires that the anchoring system used is reviewed and approved by a professional engineer.
- AC/DC lighting package

Enclosure Package Operating Characteristics

Enclosure Type	Standby ekW	Cooling Air Flow Rate		Ambient Capability*		Sound Pressure Levels (dBA) at 7m (23 ft)
		m ³ /s	cfm	°C	°F	100% Load
Level 1 Sound Attenuated Enclosure (Steel)	350	8.5	18010	57	135	74
	400	8.5	18010	56	133	75
Level 2 Sound Attenuated Enclosure (Steel)	350	7.2	15256	50	122	70
	400	7.2	15256	50	122	70
Sound Attenuated Enclosure (Aluminum)	350	8.5	–	57	135	75
	400	8.5	–	56	133	75
Weather Protective Enclosure	350	8.5	–	54	129	87
	400	8.5	–	53	127	88


Note: Sound level measurements are subject to instrumentation, installation and manufacturing variability, as well as ambient site conditions.

DIMENSIONS

Enclosure Type	Standby Ratings, ekW	Length, L		Width, W		Height, H	
		mm	in	mm	in	mm	in
Sound Attenuated Enclosure on Skid Base	350	4948	194.8	2014	79.3	2320	91.3
	400						
Sound Attenuated Enclosure on a UL Listed Integral Fuel Tank Base	350	5461	215.0	2014	79.3	2743	108.0
	400						
Sound Attenuated Enclosure on a UL Listed 660 Gallon Sub-Base Fuel Tank Base	350	4948	194.8	2056	80.9	2955	116.3
	400						
Sound Attenuated Enclosure on a UL Listed 1000 Gallon Sub-Base Fuel Tank Base	350	5751	226.4	2056	80.9	2955	116.3
	400						
Sound Attenuated Enclosure on a UL Listed 1900 Gallon Sub-Base Fuel Tank Base	350	6382	251.2	2056	80.9	3209	126.3
	400						
Sound Attenuated Enclosure on a UL Listed 2200 Gallon Sub-Base Fuel Tank Base	350	7074	278.5	2056	80.9	3209	126.3
	400						
Weather Protective Enclosure on Skid Base	350	4948	194.8	2014	79.3	2320	91.3
	400						
Weather Protective Enclosure on a UL Listed Integral Fuel Tank Base	350	5461	215.0	2014	79.3	2743	108.0
	400						

Component Weights to Calculate Package Weight

Standby ekW	Narrow Skid Base		Wide Skid Base		Sound Attenuated Enclosure (Steel)		Sound Attenuated Enclosure (Aluminum)		Weather Protective Enclosure	
	kg	lb	kg	lb	kg	lb	kg	lb	kg	lb
350 400	253	578	579	1276	1245	2745	765	1687	1166	2570



EMCP 4 CONTROL KEY FEATURES

EMCP 4 control features

- Run / Auto / Stop Control
- Speed and Voltage Adjust
- Engine Cycle Crank
- 24-volt DC operation
- Environmental sealed front face
- Text alarm/event descriptions

Digital indication for:

- RPM
- DC volts
- Operating hours
- Oil pressure (psi, kPa or bar)
- Coolant temperature
- Volts (L-L & L-N), frequency (Hz)
- Amps (per phase & average)
- ekW, kVA, kVAR, kW-hr, %kW, PF (4.2 only)

Warning/shutdown with common LED indication of:

- Low oil pressure
- High coolant temperature
- Overspeed
- Emergency Stop
- Failure to start (overcrank)
- Low coolant temperature
- Low coolant level



Programmable protective relaying functions:

- Generator phase sequence
- Over/Under voltage (27/59)
- Over/Under Frequency (81 o/u)
- Reverse Power (kW) (32) (4.2 only)
- Reverse reactive power (kVAR) (32RV)
- Overcurrent (50/51)

Communications:

- 4 digital inputs & 4 relay outputs (4.1)
- 6 digital inputs & 8 relay outputs (4.2)
- 12 digital inputs & 8 relay outputs (4.4)
- Customer data link (Modbus RTU) (4.2 only)
- Accessory module data link (4.2 only)
- Serial annunciator module data link (4.2 only)
- Emergency stop pushbutton

Compatible with the following:


- Digital I/O module
- Local Annunciator
- Remote CAN annunciator
- Remote serial annunciator

FINANCING

Caterpillar offers an array of financial products to help you succeed through financial service excellence. Options include loans, finance lease, operating lease, working capital, and revolving line of credit. Contact your local Cat dealer for availability in your region.

WORLDWIDE PRODUCT SUPPORT

Cat dealers provide extensive post-sale support including maintenance and repair agreements. Cat dealers have over 1,800 dealer branch stores operating in 200 countries. The Caterpillar® SOSSM program effectively detects internal engine component condition, even the presence of unwanted fluids and combustion by-products.



www.Cat.com/electricpower

©2019 Caterpillar All rights reserved. Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication. CAT, CATERPILLAR, their respective logos, ADEM, S•D•S, "Caterpillar Yellow", the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.


CARSON CITY PRODUCTION WELLS PERMANENT EMERGENCY GENERATORS WELL #24 PROJECT PROJECT P350518078

BOARD OF SUPERVISORS

Robert Crowell	Mayor
Stacey Giomi	Supervisor
Brad Bonkowski	Supervisor
Lori Bagwell	Supervisor
John Barrette	Supervisor
Aubrey Rowlett	City Clerk

DESIGNED FOR:

CARSON CITY PUBLIC WORKS DEPARTMENT
OPERATIONS DIVISION
3505 BUTTI WAY
CARSON CITY, NV 89701
887-2355



VICINITY MAP
N.T.S.

SHEET INDEX

- C1 TITLE SHEET
- C2 WELL #24 SITE PLAN
- C3 GENERAL NOTES AND DETAILS
- S-1.1 STRUCTURAL SLAB PLAN
- E1 ELECTRICAL LEGEND
AND DRAWING SCHEDULE
- E2 SHEET SPECIFICATIONS
- E3 ELECTRICAL ONELINE DIAGRAMS
- E4 DETAILS



DESIGNED BY: DA
DRAWN BY: JF
CHECKED BY: DA
DWG NO.: 2020JAN07
SCALE (HORIZ): 1/4"
SCALE (VERT): N/A
PLOT DATE: 2020JAN07

**CARSON CITY
PUBLIC WORKS DEPARTMENT**

3505 BUTTI WAY CARSON CITY, NEVADA 89701
PH: 887-2355 FAX: 887-2112




REV	DATE	DESCRIPTION	BY / APP'D


**CARSON CITY PRODUCTION WELLS
PERMANENT EMERGENCY GENERATORS
WELL #24 PROJECT
PROJECT No. P350518078
TITLE SHEET**

SHEET
C1
OF
08


BID SET PLANS



WELL #24 SITE PLAN
SCALE: 1" = 20'




WELL #24 GENSET
SCALE: 1/4" = 1'



DETAIL A
SCALE: 1" = 10'

REFERENCE CODES

- 2009 ICC/ANSI A117.1
- 2017 National Electrical Code
- 2018 International Building Code
- 2018 International Energy Conservation Code
- 2018 International Fire Code
- 2018 International Fuel Gas Code
- 2018 Northern Nevada International Fire Code Amendments
- 2018 Northern Nevada Amendments



Call before you Dig
Avoid cutting underground utility lines. It's costly.

Call 811
OR
1-800-227-2600

DESIGNED BY: DA
DRAWN BY: JF
CHECKED BY: DA
DWG NO. WELL#24_SIE.dwg
SCALE (HORIZ): AS SHOWN
SCALE (VERT): N/A
PLOT DATE: 2020JAN07

CARSON CITY PUBLIC WORKS DEPARTMENT
3505 BUTTI WAY CARSON CITY, NEVADA 89701
PH: 887-2355 FAX: 887-2112



REV.	DATE	DESCRIPTION	BY	APP'D

CARSON CITY PRODUCTION WELLS PERMANENT EMERGENCY GENERATORS PROJECT PROJECT No. P350518078

WELL #24 SITE PLAN

SHEET **C2** OF **08**


BID SET PLANS

- ALL WORK SHALL CONFORM TO THE "STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION" (SSPWC) AND THE "STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION" (SDPWC) AS ADOPTED BY CARSON CITY. THE CONTRACTOR SHALL OBTAIN A PERMIT FOR PUBLIC WORKS CONSTRUCTION FROM THE CARSON CITY PERMIT CENTER PRIOR TO THE START OF CONSTRUCTION.
- ALL TRAFFIC CONTROL AND BARRICADING WITHIN THE CARSON CITY RIGHT-OF-WAY SHALL CONFORM TO SECTION 100.33, 332.04 AND 332.05 OF THE STANDARD SPECIFICATIONS, PART B OF THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES, LATEST EDITION, AND THE I-17 CENTER, TEMPORARY TRAFFIC CONTROL GUIDELINES LATEST EDITION. A TRAFFIC CONTROL PLAN MUST BE SUBMITTED AND APPROVED BY THE CARSON CITY ENGINEERING DIVISION PRIOR TO ANY STREET CLOSURES.
- THE CONTRACTOR SHALL CALL UNDERGROUND SERVICE ALERT "CALL BEFORE YOU DIG" (811) OR 1-800-227-2600 AT LEAST TWO (2) WORKING DAYS PRIOR TO START OF CONSTRUCTION AND COMPLY WITH THE REQUIREMENTS OF NRS AND NAC 458 THROUGHOUT THE COURSE OF THE WORK. SEWER SERVICE LATERALS ARE NOT OWNED OR MARKED BY CARSON CITY.
- THE CONTRACTOR SHALL CALL THE CARSON CITY ENGINEERING DIVISION (887-2300) TWO (2) WORKING DAYS PRIOR TO THE START OF CONSTRUCTION. THE CONTRACTOR SHALL CALL ONE (1) WORKING DAY PRIOR TO REQUIRED INSPECTIONS AND TESTING. THE REQUIRED INSPECTIONS AND TESTING ARE LISTED ON THE INSPECTION RECORD ISSUED WITH EACH PERMIT. THE CONTRACTOR MUST HAVE THE PERMIT NUMBER AND THE DESCRIPTION LISTED ON THE INSPECTION RECORD TO SCHEDULE REQUIRED INSPECTIONS AND TESTING. FOR CITY CONTRACTED PROJECTS, THE CONTRACTOR SHALL SCHEDULE INSPECTIONS PER THE CONTRACT DOCUMENTS.
- FINAL INSPECTIONS WILL BE PERFORMED BY CARSON CITY ENGINEERING DIVISION ACCORDING TO THE CARSON CITY INSPECTIONS AND TESTING PROCEDURES. NOTE: THESE PROCEDURES REQUIRE SUBMITTAL OF RECORD DRAWING PRINTS BY THE CONTRACTOR AND 10 WORKING DAYS TO PREPARE A FINAL PUNCH LIST. ALL CONDITIONS OF THE FINAL INSPECTION MUST BE COMPLETED PRIOR TO FINAL ACCEPTANCE OR ANY APPROVAL OF A CERTIFICATE OF OCCUPANCY BY THE CARSON CITY ENGINEERING DIVISION.
- MODIFICATIONS TO THE APPROVED PLANS REQUIRES REVIEW AND APPROVAL BY THE CARSON CITY ENGINEERING DIVISION. WORK PERFORMED WITHOUT WRITTEN APPROVAL BY CARSON CITY ENGINEERING WILL REQUIRE REMOVAL AT THE CONTRACTORS EXPENSE.
- THE APPROVED PLAN, PERMIT AND INSPECTION RECORD MUST BE ON THE JOB SITE AT ALL TIMES.
- PLAN APPROVAL FOR SEWER AND WATER CONSTRUCTION SHALL EXPIRE ONE YEAR FROM DATE OF APPROVAL UNLESS CONSTRUCTION HAS BEEN INITIATED. (CCMC 12.06.180F, 12.01.140D)
- THE CONTRACTOR WILL BE SOLELY AND COMPLETELY RESPONSIBLE FOR ACQUIRING A STORMWATER DISCHARGE PERMIT FROM THE NEVADA DIVISION OF ENVIRONMENTAL PROTECTION (NDEP) INCLUDING DEVELOPING, SUBMITTING AND IMPLEMENTING A STORM WATER POLLUTION PREVENTION PLAN (SWPPP). THE CONTRACTOR SHALL DEVELOP, PLACE AND MAINTAIN STORM WATER PROTECTION DEVICES IN COMPLIANCE WITH THE NEVADA CONTRACTORS FIELD GUIDE FOR CONSTRUCTION SITE BEST MANAGEMENT PRACTICES (JUNE 2013).
- THE CONTRACTOR WILL BE SOLELY AND COMPLETELY RESPONSIBLE FOR LOCATING EXISTING UTILITIES. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO VERIFY THESE LOCATIONS AT THE PROPOSED POINTS OF CONNECTIONS AND IN AREAS OF POSSIBLE CONFLICT WITH NEW UTILITY INSTALLATION, PRIOR TO BEGINNING CONSTRUCTION. POT-HOLING IS REQUIRED. SHOULD THE CONTRACTOR FIND ANY DISCREPANCIES BETWEEN THE CONDITIONS EXISTING IN THE FIELD AND THE INFORMATION SHOWN ON THE CONSTRUCTION DRAWINGS, HE SHALL NOTIFY THE ENGINEER BEFORE PROCEEDING WITH CONSTRUCTION.
- THE CONTRACTOR WILL BE SOLELY AND COMPLETELY RESPONSIBLE FOR THE CONDITIONS OF THE JOB SITE, INCLUDING SAFETY OF ALL PERSONS AND PROPERTY DURING PERFORMANCE OF THE WORK. THIS REQUIREMENT WILL APPLY CONTINUOUSLY AND NOT BE LIMITED TO NORMAL WORKING HOURS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DESIGN AND CONSTRUCTION OF PROPER SHORING OF TRENCHES IN ACCORDANCE WITH OCCUPATIONAL SAFETY LAWS. THE DUTIES OF THE ENGINEER DO NOT INCLUDE REVIEW OF THE ADEQUACY OF THE CONTRACTORS SAFETY IN, ON, OR NEAR THE CONSTRUCTION SITE.
- SHOULD IT APPEAR THAT THE WORK TO BE DONE, OR ANY MATTER RELATIVE THERETO, IS NOT SUFFICIENTLY DETAILED OR EXPLAINED ON THE CONSTRUCTION PLANS, THE CONTRACTOR SHALL CONTACT THE ENGINEER FOR SUCH FURTHER EXPLANATIONS AS MAY BE NECESSARY.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTE 10,11,12	9/17		CARSON CITY
				DRAWING NO. C-1.1.1
				DATE SEP 2017

APPROVED BY: 9/17

GENERAL NOTES



- NOTES:**
- MINIMUM CURB RETURN RADIUS SHALL BE 15 FEET UNLESS OTHERWISE APPROVED BY THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
 - SOME STREETS MAY REQUIRE WIDER SIDEWALKS.
 - SIDEWALK ADJACENT TO TYPE 2 OR ROLLED CURB AND GUTTER SHALL BE CONSTRUCTED 5 INCHES THICK OF CONCRETE ON 6 INCHES OF AGGREGATE BASE COMPACTED TO 95%.
 - SIDEWALK SHALL BE POURED NON-MONOLITHICALLY FROM CURB AND GUTTER.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTE 3 & 4	9/17		CARSON CITY
				DRAWING NO. C-5.2.2
				DATE SEP 2017

APPROVED BY: 9/17


TYPE "A" SIDEWALK

- NO CONCRETE SHALL BE PLACED UNTIL FORMS AND SUBGRADE ARE INSPECTED AND APPROVED BY CARSON CITY PUBLIC WORKS.
- PORTLAND CEMENT CONCRETE (P.C.C.) SHALL HAVE THE FOLLOWING CHARACTERISTICS: SYNTHETIC FIBER-REINFORCEMENT (AT A MINIMUM OF 1 POUND PER CUBIC YARD), 4000 PSI MIN COMPRESSIVE STRENGTH @ 28 DAYS, MIN 6 SACKS OF CEMENT PER CUBIC YARD WITH A MAX. WATER/CEMENT RATIO OF 0.45, AIR ENTRAINMENT 6% ±1.5% SLUMP AT 1 TO 4 INCHES. ALL MATERIALS SHALL CONFORM TO SSPWC SECTION 202 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
- ALL CONCRETE EDGING AND JOINTING SHALL BE CONSTRUCTED IN ACCORDANCE WITH STD. DETAIL C-5.1.1 AND CONFORM TO SEC. 312 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC).
- IF OBSTRUCTIONS SUCH AS INLETS, UTILITY POLES, FIRE HYDRANTS, ETC. ARE ENCOUNTERED, THE LOCATION AND DIMENSIONS MAY BE ADJUSTED UPON APPROVAL BY CARSON CITY PUBLIC WORKS. A MINIMUM SURFACE OF 4 FEET X 4 FEET CLEAR IS REQUIRED WHEN DIRECTION OF TRAVEL MAY CHANGE AND A MINIMUM SURFACE OF 4 FEET CLEAR IS REQUIRED WHERE DIRECTION OF TRAVEL IS NOT EXPECTED TO CHANGE, UNLESS OTHERWISE APPROVED BY THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
- ALL CONCRETE SHALL BE REMOVED TO A NEAT SAWCUT LINE AT THE NEAREST CONTROL JOINT.
- ALL AGGREGATE BASE SHALL BE TYPE 2, CLASS B AND SHALL CONFORM TO SEC.200.01 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC).
- NEW CONCRETE SHALL HAVE A HEAVY BROOM FINISH PERPENDICULAR TO SIDEWALK.
- AC PAVEMENT EDGE SHALL BE FLUSH TO 1/4 INCH ABOVE THE LIP OF GUTTER.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTE 2,3,4,5,8	9/17		CARSON CITY
				DRAWING NO. C-5.2.1
				DATE SEP 2017

APPROVED BY: 9/17

SIDEWALK AND DRIVEWAY GENERAL NOTES



- NOTES:**
- WATER DENSIFIED BACKFILL AND TUNNELING SHALL BE BY SPECIAL PROVISION ONLY.
 - BACKFILL SHALL CONFORM TO THE REQUIREMENTS OF CLASS E BACKFILL AS SPECIFIED IN SUBSECTION 200.03.06 OF THE SSPWC. MATERIAL SHALL BE PLACED IN LIFT THICKNESS SPECIFIED IN SUBSECTION 305.10 OF THE SSPWC AND DENSIFIED TO 90% RELATIVE COMPACTION.
 - BEDDING SHALL CONFORM TO THE REQUIREMENTS OF CLASS A BACKFILL AS SPECIFIED IN SUBSECTION 200.03.02 OF THE SSPWC. MATERIAL SHALL BE DENSIFIED TO 90% RELATIVE COMPACTION.
 - PLANS SHALL INCLUDE A DETAIL FOR SUBGRADE STABILIZATION INCLUDING BACKFILL MATERIAL, STRUCTURAL GEOTEXTILE FILTER FABRIC AND MODIFIED CUTOFF COLLARS WHEN POTENTIAL FOR UNSTABLE SUBGRADES EXIST, SUBJECT TO THE APPROVAL OF THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
 - FOR TRENCHES IN ROADWAY SECTION, SEE PAVEMENT PATCH DETAIL (DWG. NO. C-5.1.6).
 - FOR THE PURPOSE OF PAYMENT; EXCAVATION AND BACKFILL QUANTITIES ARE BASED ON THESE STANDARD DRAWINGS, AND NO ADDITIONAL COMPENSATION WILL BE MADE. SHORING OR SLOPED CUT SLOPES MAY BE NECESSARY, BUT THERE WILL BE NO ADDITIONAL PAYMENT. ALL EXCAVATIONS SHALL CONFORM TO THE LATEST O.S.H.A. REQUIREMENTS.
 - PLACE WARNING TAPE 1 FOOT ABOVE ALL BURIED PIPES AND CONDUITS.
 - TRACER WIRE SHALL BE 12 GAUGE (MINIMUM THICKNESS) INSULATED SOLID COPPER WIRE. INSULATION SHALL BE 30 MIL HDPE. PLANS SHALL SPECIFY WIRE STRENGTH AND INSULATION THICKNESS FOR BORING APPLICATIONS. SPLICES SHALL BE CONNECTED BY WIRE NUTS, SEALED WITH AQUA SEAL OR SILICON FILLED, AND DOUBLE WRAPPED WITH U/L LISTED ELECTRICAL TAPE. TRACER WIRE COLOR SHALL BE BLUE FOR WATER, PURPLE FOR RECLAIMED WATER, GREEN FOR SEWER AND YELLOW FOR ELECTRICAL OR FIBER OPTIC.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTE 8	9/17		CARSON CITY
				DRAWING NO. C-1.2.1 (305)
				DATE SEP 2017

APPROVED BY: 9/17


TRENCH EXCAVATION AND BACKFILL

- NO CONCRETE SHALL BE PLACED UNTIL FORMS AND SUBGRADE ARE INSPECTED BY CARSON CITY PUBLIC WORKS.
- PORTLAND CEMENT CONCRETE (P.C.C.) SHALL HAVE THE FOLLOWING CHARACTERISTICS: SYNTHETIC FIBER-REINFORCEMENT (AT A MINIMUM OF 1 POUND PER CUBIC YARD), 4000 PSI MIN COMPRESSIVE STRENGTH @ 28 DAYS, MIN 6 SACKS OF CEMENT PER CUBIC YARD WITH A MAX. WATER/CEMENT RATIO OF 0.45, AIR ENTRAINMENT 6% ±1.5% SLUMP AT 1 TO 4 INCHES. ALL MATERIALS SHALL CONFORM TO SSPWC SECTION 202 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
- ALL CONCRETE EDGING AND JOINTING SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD DETAILS C-5.1.1 AND C-5.1.3 AND CONFORM TO SECTION 312 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC).
- ALL AGGREGATE BASE SHALL BE TYPE 2, CLASS B AND CONFORM TO SECTION 200.01 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION, AND SHALL BE MECHANICALLY COMPACTED TO 95% COMPACTION, IN CONFORMANCE WITH SECTION 308.05 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
- CURB & GUTTER SHALL BE POURED SEPARATELY/NON-MONOLITHICALLY FROM SIDEWALK.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTES 2 & 4	9/17		CARSON CITY
				DRAWING NO. C-5.1.3
				DATE SEP 2017

APPROVED BY: 9/17

PCC CURB & GUTTER TYPE 1



- NOTES:**
- NO CONCRETE SHALL BE PLACED UNTIL FORMS AND SUBGRADE ARE INSPECTED BY CARSON CITY PUBLIC WORKS.
 - ALL CONCRETE EDGING AND JOINTING SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD DETAILS C-5.1.1 AND C-5.1.3 AND CONFORM TO SEC. 312.09 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC).

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTE 2	9/17		CARSON CITY
				DRAWING NO. C-5.3.10
				DATE SEP 2017

APPROVED BY: 9/17


P.C.C. RETAINING CURB

- IF SAWCUT IS WITHIN 24 INCHES OF EDGE OF A.C. PAVEMENT REMOVE EXISTING PAVEMENT TO THAT EDGE AND REPLACE ENTIRE SECTION.
- BITUMINOUS MATERIAL SHALL MEET THE REQUIREMENTS OF SECTIONS 201 AND 320 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION.
- MIXING, SPREADING, AND COMPACTING OF BITUMINOUS PAVEMENT SHALL BE DONE ONLY WHEN THE SURFACE ON WHICH THE MATERIALS ARE TO BE PLACED IS DRY AND WHEN THE ATMOSPHERIC TEMPERATURE IS ABOVE 50 DEGREES FAHRENHEIT AND HAS NOT BEEN BELOW 40 DEGREES FAHRENHEIT DURING THE PRECEDING 24 HOURS.
- FINISHED SURFACE VARIATIONS SHALL BE 0 TO 0.25 INCHES ABOVE EXISTING SURFACE. ALL HUMPS EXCEEDING THIS TOLERANCE SHALL BE CORRECTED BY REMOVAL OF MATERIAL AND REPLACING IT WITH NEW MATERIAL. FINISHED SURFACE OF PATCH SHALL NOT BE BELOW EXISTING ADJACENT SURFACE.
- PLANTMIX BITUMINOUS PAVEMENT SURFACE AND SUB SURFACE COURSES SHALL BE PG-64-22 TYPE 3 WITH LIME SLOW BLOW AND 15% RAP MAX. UNLESS OTHERWISE NOTED.
- PLANTMIX BITUMINOUS PAVEMENT PATCHES SHALL MATCH EXISTING SECTION OR HAVE A MINIMUM THICKNESS OF 5 INCHES, WHICHEVER IS GREATER.
- PLANS SHALL SPECIFY PAVEMENT PATCH AND AGGREGATE BASE DEPTHS AS SPECIFIED BY THE DESIGN ENGINEER.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	5" AC DEPTH	09/11		CARSON CITY
Δ	NOTE 5	9/17		DRAWING NO. C-5.1.8
				DATE SEP 2017

APPROVED BY: 9/17

PAVEMENT PATCH



NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
Δ	NOTE 2	9/17		CARSON CITY
				DRAWING NO. C-5.3.10
				DATE SEP 2017

APPROVED BY: 9/17

DESIGNED BY: DA
 DRAWN BY: UF
 CHECKED BY: DA
 DWG NO.: 2020JAN07
 SCALE (HORIZ): N/A
 SCALE (VERT): N/A
 PLOT DATE: 2020JAN07

CARSON CITY PUBLIC WORKS DEPARTMENT

3505 BUTTI WAY CARSON CITY, NEVADA 89701
 PH: 887-2355 FAX: 887-2112

DARREN S. ANDERSON
 CIVIL ENGINEER - STATE OF NEVADA
 Exp: 12/31/20
 No. 23718

2/10/2020

BY: APP'D

REV.	DATE	DESCRIPTION

CARSON CITY PRODUCTION WELLS PERMANENT EMERGENCY GENERATORS WELL 41 PROJECT PROJECT No. P350518078 GENERAL NOTES AND DETAILS

SHEET **C3** OF **8**

BID SET PLANS

CCPW Well Generators

Various Locations
Carson City, Nevada

Ashley & Vance
ENGINEERING, INC.
7530 Longley Lane, Suite 105
Reno, NV 89511
(775) 825-8945
www.ashleyvance.com

CIVIL • STRUCTURAL

STANDARD SPECIFICATIONS



- CONCRETE**
- All concrete shall have:
 - an ultimate compressive strength (F_c) of 3,000 psi at 28 days (UNO)
 - a maximum slump of 5" at point of placement.
 - a W/C ratio of 0.55 or less for all slabs, walls, and columns, and 0.50 or less for all foundations.
 - a normal dry-weight density (UNO)
 - Special inspection is NOT required as the foundations have been designed with f_c = 2,500 psi in accordance with the Governing Building Code, section 1705.3, exceptions 1, 2.1, and 2.3, unless explicitly specified herein, on the structural plans, or by the Building Department. As a minimum, special inspection is always required on:
 - structural slabs, flat plates
 - walls, columns, beams
 - piers, caissons
 - welding of reinforcement, installation of mechanical bar splice devices, epoxy application
- When required or specified, special inspection services shall conform to the Governing Building Code, Chapter 17 and shall be provided by an ICC certified inspector or Building Department approved engineer. The Building Department reserves the right to waive or require the special inspection requirements [Section 1704.1 and 1704.4]. Nothing in these plans waives the Building Department's right to require special inspection at any point and on any materials.
- Testing of materials used in concrete construction must be performed as noted on structural plans or as the result of the Building Department to determine if materials are quality specified. Tests of materials and of concrete shall be made by an approved agency and at the expense of the contractor, such tests shall be made in accordance with the standards listed in the Governing Building Code, Table 1704.4. When testing of concrete is required, four (4) test cylinders shall be taken from each 150 yards, or fraction thereof, poured in any one day. One (1) cylinder shall be tested at seven (7) days, two (2) at 28 days, one (1) shall be held in reserve. If Contractor elects to have additional tests performed for "early-break" results, additional test cylinders must be taken. At no time shall the Contractor instruct the testing agency to perform tests on a schedule different than above without the prior authorization of the Engineer. Contractor is responsible for complying with applicable testing requirements of the Building Department. Copies of all test reports shall be provided to Engineer and Building Department for review in a timely manner.
- The Contractor shall remove and replace any concrete which fails to attain specified 28 day compressive strength if so directed by the Engineer. Any defects in the hardened concrete shall be repaired at the Contractor's expense.
 - All concrete work shall conform with the Governing Building Code, Chapter 18
 - All cement shall be Portland Cement Type I or II and shall conform to ASTM C 150.
 - All aggregates shall conform to ASTM C 33. Maximum aggregate sizes:
 - Footings: 1-1/2"
 - All other work: 3/4"
 - Where not specifically detailed, the minimum concrete cover on reinforcing steel shall be:
 - Permanently exposed to earth or weather:
 - Cast against earth: 3"
 - Cast against forms: 2"
 - Not exposed to earth or weather:
 - Slabs, walls, joists: 3/4"
 - Beams, girders, columns: 1-1/2"
 - The minimum lap splice length for all reinforcing steel shall be as noted in the typical details on sheet S-1.1. All lap splices to be staggered.
 - All reinforcing steel, anchor bolts, dowels, inserts, and any other hardware to be cast in concrete shall be well secured in position prior to foundation inspection. All hardware to be installed in accordance with respective manufacturer's specifications. Refer to architectural and structural plans for locations of embedded items.
 - Locations of all construction joints, other than specified on the structural plans, shall be approved by the Architect and Engineer prior to forming. Construction joints shall be thoroughly air and water cleaned and heavily roughened so as to expose coarse aggregate. All surfaces to receive fresh concrete shall be maintained continuously wet at least three (3) hours in advance of concrete placement. Unless specifically detailed or otherwise noted, construction and control joints shall be provided in all concrete slabs-on-grade. Joints shall be located such that the area does not exceed 400 sq. feet.
 - The Architect, Engineer and appropriate inspectors shall be notified in a timely manner for a reinforcement inspection prior to the placement of any concrete.
 - The Contractor shall obtain approval from the Architect and the Engineer prior to placing sleeves, pipes, ducts, chases, coting and opening on or through structural concrete beams, walls, floors, and roof slabs unless specifically detailed or noted on the plans. All pipes or conduits passing through concrete members shall be sleeved with standard steel pipe sections.
 - The Contractor is responsible for design, installation, maintenance and removal of all formwork. Forms shall be properly constructed, sufficiently tight to prevent leakage, sufficiently strong, and braced to maintain their shape and alignment until no longer needed for concrete support. Joints in formwork shall be tightly fitted and blocked, and shall produce a finished concrete surface that is true and free from blemishes. Forms for exposed concrete shall be pre-approved by the Architect to ensure conformance with design intent.
 - Remove form work in accordance with the following schedule:
 - Forms at slab edge: 1 day
 - Side forms at footings: 2 days
 - All other vertical surfaces: 7 days
 - Beams, columns, girders: 15 days
 - Elevated slabs: 28 days
- Engineer reserves the right to modify removal schedule above based on field observations, concrete conditions, and/or concrete test results.
- All concrete (except slabs-on-grade 6" or less) shall be mechanically vibrated as it is placed. Vibrator to be operated by experienced personnel. The vibrator shall be used to consolidate the concrete. The vibrator shall not be used to convey concrete, nor shall it be placed on reinforcing and/or forms.
 - Concrete shall be maintained in a moist condition for a min. of five (5) days after placement.
 - Concrete shall not be permitted to freeze for more than six (6) feet. For heights greater than six (6) feet, use brine, pump or other method consistent with applicable standards.
 - When specified ultimate compressive strength is greater than 2500 psi, Contractor shall submit mix designs to Architect and Engineer for approval seven (7) days prior to placement. Mix designs shall be prepared by an approved testing laboratory. Sufficient data must be provided for all admixtures.
 - Refer to Architectural plans for locations of all dimensions, slab depressions, slopes, drains, curbs, and control joints.

- REINFORCEMENT**
- Reinforcing steel shall be to deformed, clean, free of rust, grease or any other material likely to impair concrete bond.
 - All bars shall conform to ASTM A615, Grade 60 minimum (UNO on structural plans). All weld wire fabric (WWF) shall conform to ASTM A185.
 - Reinforcing steel that is to be welded shall conform to ASTM A706. All welding of reinforcement shall be subject to special inspection.
 - Contractor shall take necessary steps (standard ties, anchorage devices, etc.) to secure all reinforcing steel in their true position and prevent displacement during concrete placement.
 - Fabrication, placement and installation of reinforcing steel shall conform to:
 - Concrete Reinforcing Steel Institute (CRSI) Manual of Standard Practice
 - the Governing Building Code, Section 1907
 - Shop drawings for fabrication of reinforcing steel shall be approved by the Contractor and submitted to the Architect and Engineer for review and approval prior to fabrication. Shop drawings are not required for slabs-on-grade or foundations unless specifically noted on the structural plans.
 - Heating of reinforcing steel to aid in bending and shaping of bars is not permitted. All bends in reinforcing steel are to be made cold. All bend radii shall conform to CRSI Manual of Standard Practice.
 - Refer to Concrete and Masonry notes for specific minimum splice length and splice staggering requirements. Lap welded wire fabric (WWF) reinforcement two (2) modules minimum (UNO). All splices are to be staggered.
- FOUNDATIONS**
- Refer to Structural Design Parameters section on sheet S-1.1 for all soil design values used in calculations.
 - Soils values per Table 1806.2 of the latest edition of the Governing Building Code.
 - Unexpected Soil Conditions. Allowable values and subsequent foundation designs are based on soil conditions which are shown by test borings. Actual soil conditions which deviate appreciably from that shown in the test borings shall be reported to the Engineer immediately.
 - All compaction, fill, backfilling and site preparation shall be performed in accordance with project soils report or the Governing Building Code Chapter 18 & Appendix J. All such work shall be performed under the supervision of the building official.
 - Excavate to required depths and dimensions (as indicated in the drawings), cut square and smooth with firm level bottoms. Care shall be taken not to over-excavate foundation at lower elevation and prevent disturbance of soils around (H/W) excavation.
 - Foundations shall be poured in neat excavations.
 - Excavate all foundations to required depths into compacted fill or natural soil (as per plans and details) and as verified by the building official and/or soils engineer.
 - All foundations shall be inspected and approved by the building official and/or a representative of the soils engineer prior to forming and placement of reinforcing or concrete.
 - Foundations shall not be poured until all required reinforcing steel, framing hardware, sleeves, inserts, conduits, pipes, etc. and formwork is properly placed and inspected by the appropriate building official/inspector(s).
 - It is the responsibility of the contractor in charge of framing to properly position all holdown bolts, anchor bolts, column bases, and all other cast-in-place hardware. Refer to typical details. All hardware to be secured prior to foundation inspections.
 - The sides and bottoms of dry excavations must be maintained just prior to placing concrete. Conversely, de-water footings as required to remove standing water and to maintain optimum working conditions.
 - The Contractor shall be solely responsible for all excavation procedures including lagging, shoring, and the protection of adjacent property, structures, streets, and utilities in accordance with all federal, state and local safety ordinances. The Contractor shall provide for the design and installation of all cribbing, bracing and shoring required.
- STATEMENT OF SPECIAL INSPECTIONS, 2018 IBC**
- This Statement of Special Inspection is submitted in fulfillment of the requirements of the Governing Building Code, section 1704 and 1705.
 - Special Inspections and Testings will be performed in accordance with the approved plans and specifications, this statement and the Governing Building Code, Section 1704, 1705, 1707, and 1708.
 - The schedule of Special Inspections summarizes the Special Inspections and tests required. Special Inspectors will refer to the approved plans and specifications for detailed special inspection requirements. Any additional tests and inspections required by the approved plans and specifications will also be performed.
 - Interim reports will be submitted to the Building Official and the Registered Design Professional in Responsible Charge in accordance with the Governing Building Code Section 1704.2.4.
 - A Final Report of Special Inspections documenting required Special Inspections, testing and correction of any discrepancies noted in the inspections shall be submitted prior to issuance of a Certificate of Use and Occupancy (Section 1704.2.4). The Final Report will document:
 - Required special inspections.
 - Correction of discrepancies noted in inspections.
 - The Owner recognizes his or her obligation to ensure that the construction complies with the approved permit documents and to implement the program of special inspections. In partial fulfillment of these obligations, the Owner will retain and directly pay for the Special Inspections as required in the Governing Building Code, Section 1704.2.
 - 1704.4 Contractor responsibility. Each contractor responsible for the construction of a main wind- or seismic-force-resisting system, designated seismic system or a wind- or seismic-resisting component listed in the statement of special inspections shall submit a written statement of responsibility to the building official and the owner prior to the commencement of work on the system or component. The contractor's statement of responsibility shall contain acknowledgment of awareness of the special requirements contained in the statement of special inspection.

Verification & Inspection	C	P	Notes
1705.3 - Concrete			
4. Inspect anchors post-installed in hardened concrete			
a. Adhesive anchors installed in horizontally or upwardly inclined orientations to resist sustained tension	X		
b. Mechanical anchors and adhesive anchors not defined in 4.a		X	

FOOTNOTES:

- Prior to epoxy placement, it must be verified that the hole is clean, dry, and free of loose debris.
- Periodic inspection shall take place such that the installation of a minimum of two (2) anchors per each shear wall are observed.



GENERAL FOUNDATION NOTES

Foundations per Governing Building Code, Table 1806.2
At the request of the client (or client's agent), Ashley & Vance Engineering has designed the foundations in conformance with Table 1806.2. If the building official determines that expansive soils are present, or other geologic issues of concern, then they may require that special provisions be made to the foundation design to safeguard against damage due to the expansiveness or due to other geologic issues. If this becomes the situation, all foundation construction must be halted and the client, at their own expense, shall: (a) obtain a soils report prepared by a Soils Engineer licensed in the state of the project; (b) commission Ashley & Vance Engineering to revise the foundation plans and details, and framing plans if necessary, to reflect the recommendations of the soils report; (c) submit the revised plans to the Building Department for approval.

Foundation per Details:
18" Wide x 24" Embedment w/ (2) #4 Top & Bot. (UNO)
8" Slab-on-Grade w/ #4 @ 12" oc per Details

See General Notes & Specifications for additional requirements and material specifications.
All dimensions per Architectural plans
Contractor to VERIFY all dimensions of Architectural plans PRIOR to commencement of construction.

ABBREVIATIONS		PROJECT INFORMATION	
AB	Anchor Bolt	Max.	Masonry
Ab	Above and Below	MS	Machine Bolt
Abv	Above	Mfr	Manufacture(r)
Adj.	Addition (all)	Min.	Minimum, Minute
Adj.	Adjacent, Adjustable	Mod	Modif(y), (ication)
Alt.	Alternate (ive)	NI	New
Appd.	Approved	Mod	Modif(y), (ication)
Arch.	Architect(ural)	Mod	Modif(y), (ication)
Av	Average	N/A	Not Applicable
Bdy	Boundary	Nat.	Natural
Bldg.	Building	NTS	Not to Scale
Bm	Beam	o/c	On Center
B-O	Bottom of	OD	Outside Diameter
BO	By Others	Oprng	Opening
Bot	Bottom	Opp	Opposite
Br	Bracing	Opt.	Optional
Btwm	Between	Paralel	Parallel
B/W	Between Ways	PCF	Lbs per Cubic Ft
Can	Can't (ive)	PSF	Lbs per Square Ft
CIP	Cast in Place	Perf	Perforated, (tion)
CJP	Ceiling Joist	Perf	Perforated
CJP	Complete Joint	Perim	Perimeter
CL	Center Line	Perp	Perpendicular
Cig.	Ceiling	Panel	Panel Index
Com.	Common	Prep.	Prepare, (tion)
Comp.	Component	Press	Pressure
Conc.	Concrete	Proj.	Project
Conn.	Connection	Prop.	Property
Const.	Construction	PSF	Lbs per Square Ft
Cont.	Continue (ous)	PSI	Lbs per Square In
Cr.	Center	R	Radius
d	Penry	Rec(s)	Recommendation(s)
DBI	Double	Rect.	Rectangular
Defl	Deflection	Ref.	Reference
Dep	Depressed	Reinf.	Reinforce(d), (ment)
Di	Diameter	Req(d)	Require(d)
Diap.	Diaphragm	Reqs.	Requirements
Dif.	Different	Ret.	Retain(ing)
Dim	Dimension	Sched.	Schedule
Dist.	Distances	Sgl	Single
D/L	Dead Load	Shg	Sheathing
Dwg	Drawing	Sim.	Similar
(E)	Existing	SIP	Str Insulated Panel
EA	Each	SM	Sheet Metal
EF	Each Face	SMS	Sheet Metal Screw
EFP	Equivalent Fluid Pressure	SOG	Slab on Grade
Elev	Elevator, Elevation	Spec	Specif(ied), (ication)
Embed	Embed(ed), (ment)	Std	Standard
Eng	Engineer	Sym.	Symmetry, (ical)
EOR	Engineer of Record	T&B	Top and Bottom
Eq	Equal, Equivalent	Temp	Temporary
EW	Each Way	Thk.	Thick(ness)
Exp	Expand, Expansion	Thru	Through
Ext.	Exterior	TOC	Top of Concrete
Fdn	Foundation	TOG	Top of Grade
FOC	Face of Concrete	TOM	Top of Masonry
Fmg	Framing	TOS	Top of Steel
FL	Foot, Feet	TOW	Top of Wall
FC	Foot, Feet	TRU	To Remain
FG	Foot, Feet	Unchd	Unchanged
GC	General Contractor	Tmr	Trimmer
Ht	Height	Typ.	Typical
In	Inch(es)	UNO	Unless Noted
Insp.	Inspection	W	Otherwise
K	Kips (1,000 pounds)	w/	With
L(b)s	Location	w/o	Without
Loc.	Location		

CLIENT:
Carson City Public Works Department
3505 Bush Way
Carson City, NV 89701

DESIGNER:
Carson City Public Works Department
3505 Bush Way
Carson City, NV 89701
(775) 887-2355

DESIGN PARAMETERS

GENERAL PARAMETERS

Building Code: 2018 IBC*

SOILS VALUES (Table 1806.2)

Bearing Pressure: 1500 pcf
Lateral Passive EFP: 130 pcf
At-Rest EFP: 80 pcf
Active EFP: 40 pcf

WIND DESIGN BASIS

Ultimate Wind Speed, V_{ULT}: 130 mph
Nominal Wind Speed, V_{ASD}: 101 mph
Risk Category: II
Exposure: C
Importance Factor, I_w: 1.00




SEISMIC DESIGN BASIS

Seismic Design Category: E
Site Class: D
Seismic Factors: S_B / S₁: 2.406 / 0.903
S_B / S_{0.1}: 1.504 / 0.903
Risk Category: II
Importance Factor, I_w: 1.00
Design Base Shear: V = 0.8084V
Analysis Procedure: ASCE 7-10, 13.3

* The 2018 International Building Code (IBC), is the governing code in the State of Nevada.

SHEET INDEX

S-1.1 Structural Specifications, Plans, and Details



The use of these plans and specifications shall be restricted to the original site for which they were prepared and publication thereof is expressly limited to such use. Reproduction or publication by any method, in whole or in part, is prohibited. Title to these plans and specifications remain with Ashley & Vance Engineering, Inc. without prejudice. Visual contact with these plans and specifications shall constitute prima facie evidence of the acceptance of these restrictions.



CCPW Well Generators
Various Locations
Carson City, Nevada

Proj. Engr: M. Schiano	Phone Ext. 162
Proj. Mng: J. Denio	Phone Ext.
Date: 13 Mar 2019	Scale: NTS
A&V Job No.: 19092	


STRUCTURAL SPECIFICATIONS, PLANS, AND DETAILS
S-1.1

GENERAL NOTES


- (X) AND/OR DASHED LINES INDICATE EXISTING EQUIPMENT TO BE REMOVED, (E) AND/OR HALFTONE LINES INDICATE EXISTING EQUIPMENT, (N) AND/OR SOLID LINES INDICATE NEW EQUIPMENT UNLESS NOTED OTHERWISE.
- ALL CONDUCTOR SIZES ARE BASED ON COPPER. ALUMINUM IS NOT PERMITTED.
- PANELBOARD AND BREAKER INTERRUPTING CAPACITIES (AIC) SHALL BE FULLY RATED AS AN ASSEMBLY. SERIES RATINGS OF BREAKER DEVICES AND EQUIPMENT IS NOT PERMITTED.
- ALL SWITCHBOARDS AND DISTRIBUTION BOARDS SHALL BE FULLY BUSSED.
- CONDUCTORS SHALL BE TYPE THN/THHN 90 DEGREE C RATED.
- ALL WORK SHALL BE IN ACCORDANCE WITH NEC AND LOCAL CODES.
- PROVIDE ENGRAVED NAMEPLATES FOR ALL EQUIPMENT.
- COORDINATE ALL OUTAGES WITH OWNER PRIOR TO TAKING EQUIPMENT OUT OF SERVICE.
- ALL WORK SHALL BE COORDINATED WITH OWNER AND ALL OTHER CONTRACTORS ON SITE. WORK REQUIRING SHUTDOWNS OF PANELS AND EQUIPMENT SHALL BE COORDINATED IN ADVANCE. EFFORT SHALL BE MADE TO MINIMIZE DOWNTIME. AFFECTED AREAS SHALL BE KEPT TO A MINIMUM. THE MAXIMUM DURATION FOR DOWNTIME TO ANY PART OF THE FACILITY SHALL BE NO LONGER THAN 6 HOURS. CONTRACTOR SHALL SUBMIT WRITTEN REQUEST FOR DOWNTIME A MINIMUM OF 5 DAYS PRIOR TO ACTUAL SHUTDOWN.
- ALL CONDUCTORS SHALL BE ADEQUATELY LABELED PRIOR TO DISCONNECTION.

SHEET NOTES

- DISCONNECT NEUTRAL/GROUND BOND IN EXISTING EQUIPMENT.
- REMOVE EXISTING HV ENERGY SECONDARY CONDUCTORS FROM TRANSFORMER TO SERVICE ENTRANCE CONDUIT TO BE RE-USED AND EXTENDED TO NEW ATS. SEE SITE PLAN FOR LOCATION.
- REMOVE EXISTING HV ENERGY SECONDARY CONDUCTORS FROM TRANSFORMER TO METER/DISCONNECT. CONDUIT TO BE RE-USED AND INTERCEPTED/EXTENDED. SEE SITE PLAN.
- DEMOLISH CONDUCTORS BETWEEN PANELBOARD AND GENERATOR. ABANDON CONDUIT IN PLACE. SEE SITE PLAN.
- PROVIDE AND INSTALL SERVICE ENTRANCE RATED AUTOMATIC TRANSFER SWITCH (ATS): 800A, 480V, 4-POLE, NEMA 3R, OPEN TRANSITION.
- CONTRACTOR SHALL PROVIDE CONCRETE EQUIPMENT PAD PER MANUFACTURER'S REQUIREMENTS.
- CONTRACTOR TO PROVIDE AND INSTALL SUPPLEMENTAL GROUND ELECTRODE AT GENERATOR. LENGTH SHALL BE MINIMUM 20'-0" OF #4 BARE COPPER UFER GROUND IN GENERATOR EQUIPMENT FOOTING/PAD AND BOND TO GENERATOR GROUND BAR AS REQUIRED PER NEC 250.52.
- PROVIDE (B) #14 WIRE.
- PROVIDE (B) #14 WIRE AND (1) CAT-6 SHIELDED CABLE. VERIFY WITH OWNER FOR TERMINATION LOCATION.
- PROVIDE NEW CIRCUIT BREAKER IN EXISTING SPACE. PROVIDE ALL MOUNTING HARDWARE AS REQUIRED. MATCH TYPE AND AIC RATING OF EXISTING EQUIPMENT.
- PROVIDE NEW 200A, 120/240V, 3PH, 4W POWER PEDESTAL WITH DISTRIBUTION. RE-USE EXISTING PAD AND CONDUIT TO RE-FEED PANEL.
- SEE E4 FOR CIRCUITING INFORMATION.



A E3 ELECTRICAL ONELINE DIAGRAM - DEMOLITION
SCALE: NONE



A E3 ELECTRICAL ONELINE DIAGRAM - NEW
SCALE: NONE

FEEDER SCHEDULE (600V, 3Ø, 3W)

FEEDER	AMPERE	WIRE (CU)	BOND (CU)	CONDUIT
403	40	(3) 8	10	3/4"
503	50	(3) 6	10	1"
603	60	(3) 4	10	1"
703	70	(3) 4	10	1 1/4"

FEEDER SCHEDULE (600V, 3Ø, 4W)

FEEDER	AMPERE	WIRE (CU)	BOND (CU)	CONDUIT
404	400	(4) 500K	3	4"
504	500	(8) 250K	(2) 2	(2) 2 1/2"
604	600	(8) 350K	(2) 1	(2) 5"
804	800	(8) 500K	(2) 1/0	(2) 4"

DESIGNED BY: DGB/DGA
DRAWN BY: EDD/GR
CHECKED BY: DGA
DWG NO.: 1003.E3.01 (Rev. 04/17/20)
SCALE: (NOR): N/A
SCALE: (VIRT): N/A
PLOT DATE: 2/6/20

CARSON CITY PUBLIC WORKS DEPARTMENT
3505 BUTTI WAY CARSON CITY, NEVADA 89701
PH: 867-2355 FAX: 867-2112

PROFESSIONAL ENGINEER - STATE OF NEVADA
JOSEPH E. GANSEY
EXP. 12/15/17
No. 2104 L. J. V. 10000
02/06/2020

REV.	DATE	DESCRIPTION	BY	APP'D

CARSON CITY PRODUCTION WELLS #24
PERMANENT EMERGENCY GENERATORS PROJECT
PROJECT NO. 9.18.11

ELECTRICAL ONELINE DIAGRAMS

SHEET **E3** OF



PK Electrical, Inc.
Engineering · Design · Consulting

481 Sierra Road Dr., Ste. B | Reno, Nevada 89511 | 775.825.9240
1525 27C Parkway Suite 420 | Greenwood Village, Colorado 80111 | 720.481.1290
pk-electrical.com © 2018-2019 PK Electrical, Inc. 2/2020

Call before you Dig
Avoid cutting underground utility lines. It's costly.

Call 811

or
1-800-227-2600




LOAD CALCULATION: [E] DIST. BOARD - 800A

LOAD DESCRIPTION	LIGHTING	RECEPTS	EQUIP.	MOTOR	KITCHEN	HEAT	TOTAL
(E) HVAC 1				7,500			7,500
(E) HVAC 2				7,500			7,500
(E) PNL A			8,900				8,900
(E) WELL PUMP VFD				287,600			287,600
(E) LIFT STATION GENERATOR PANEL			5,800	25,900			26,900
							5,800
Total Connected Load:				14,700	329,500		344,200
Largest Motor:					287,600		
NEC Demand Factor	100%	100% 1st 10KW 50% for rest	100%	100% + 25% of Largest Load	65%	100%	
NEC Code Reference	NEC 220.42	NEC 220.44		NEC 430.24	NEC 220.56	NEC 220.51	
Total Demand Load:				14,700	401,400		416,100
NEC Load:				416,100	at 480/277V		500.5 Amperes

© 2008-2014 PK ELECTRICAL, INC.

RACEWAY LEGEND

NO.	CONDUIT SIZE	LOCATION (TO FROM)
1	2" C. W (B) #14	ATS TO TELEMETRY
2	2" C. W CAT-6	ATS TO TELEMETRY
3	(2) 4" C. W (4) 500K #1/0G	ATS TO GENERATOR
4	2" C. W (B) #14	GENERATOR TO TELEMETRY
5	2" C. W CAT-6	GENERATOR TO TELEMETRY
6	(1) 4" C.	(E) UTILITY XF TO ATS
7	(2) 4" C. W (4) 500K #1/0G	FULLBOX TO GEN TAP BOX



B TYPICAL 2 CONDUIT TRENCH DETAIL
E4 SCALE: NONE


C N-36 CONCRETE BOX
E4 SCALE: NONE

GENERAL NOTES

- (X) AND/OR DASHED LINES INDICATE EXISTING EQUIPMENT TO BE REMOVED, (E) AND/OR HALF TONE LINES INDICATE EXISTING EQUIPMENT, (R) AND/OR DASHED LINES INDICATE EXISTING EQUIPMENT TO BE RELOCATED, (N) AND/OR SOLID LINES INDICATE NEW EQUIPMENT, UNLESS NOTED OTHERWISE.
- REPAIR AND REPLACE ALL LANDSCAPING AND SITEWORK DISTURBED BY EXCAVATION INCLUDING BUT NOT LIMITED TO IRRIGATION LINES, LAWNS, PLANTING, ETC.
- PAINT EXPOSED BUILDING MOUNTED CONDUITS TO MATCH EXISTING FINISH.
- IT IS THE CONTRACTOR'S RESPONSIBILITY TO CALL 1-800-227-2600 FOR LOCATES PRIOR TO DIGGING. IT IS ALSO THE CONTRACTOR'S RESPONSIBILITY TO LOCATE ALL NON-UTILITY UNDERGROUND ITEMS.
- THE CONTRACTOR SHALL REMOVE FROM THE JOB SITE ALL ABANDONED MATERIALS LEFT OVER FROM DEMOLITION. ITEMS MAY INCLUDE, BUT ARE NOT LIMITED TO, CONDUIT, FASTENERS AND BOXES.

SHEET NOTES

- REMOVE CONDUCTORS FROM CONDUIT. RE-USE CONDUIT FOR NEW FEED TO EXISTING RIVERVIEW LIFT STATION. SEE ONLINE DIAGRAM.
- EXISTING UNDERGROUND CONDUIT AND WIRING TO REMAIN AND BE RE-USED.
- REMOVE GENERATOR PAD, AND WIRING BACK TO SOURCE. DEMOLISH CONDUIT ABOVE GRADE AND CAP CONDUITS. REMOVE CONCRETE PAD. COORDINATE WITH CIVIL DRAWINGS. GENERATOR TO BE TURNED OVER TO OWNER.
- DEMOLISH REMOTE METER, DISCONNECT, AND SUPPORTS. CAP CONDUITS AT GRADE AND REMOVE CONDUCTORS TO EXISTING IN-GROUND FULLBOX.
- INTERCEPT EXISTING CONDUIT (NOTE 2) IN VICINITY OF NV ENERGY TRANSFORMER. EXTEND 2" PVC TO NEW JUNCTION BOX AS SHOWN. COORDINATE ALL WORK WITH NV ENERGY. REMOVE SIDEWALK/LANDSCAPING AS REQUIRED. PATCH AND REPAIR ALL WORK UPON COMPLETION.
- SPLICE AND EXTEND FEEDER FROM PEDESTAL MOUNTED PANELBOARD TO EXISTING LIFT STATION WHERE GENERATOR IS REMOVED FROM SYSTEM. EXISTING LIFT STATION TO BE FED FROM Y88. SEE ONLINE DIAGRAM.
- RE-ROUTE AND EXTEND EXISTING CONDUIT FROM REMOVED DISCONNECT TO EXISTING FULL BOX.
- SEE ONLINE FOR NEW PEDESTAL PANEL REQUIREMENTS. EXTEND ALL CONDUIT AND WIRING AS REQUIRED TO NEW BRANCH BREAKERS.



A ELECTRICAL SITE PLAN
E4 SCALE: 1" = 20'-0"



CARSON CITY PRODUCTION WELLS #24
PERMANENT EMERGENCY GENERATORS PROJECT
PROJECT NO. 9.1811
ELECTRICAL SITE PLAN

SHEET
E4
OF
*



REV.	DATE	DESCRIPTION	BY	APP'D

DESIGNED BY: DGB/DGA
DRAWN BY: BDD/GR
CHECKED BY: DGA
DWG NO.: 10013 (4 Electrical Site Plan)
SCALE (HORIZ): N/A
SCALE (VERT): N/A
PLOT DATE: 2/6/20

CARSON CITY
PUBLIC WORKS DEPARTMENT
3505 BUTTE WAY CARSON CITY, NEVADA 89701
PH: 887-2355 FAX: 887-2112