



ISOMETRIC VIEW
NTS

NOTES:

1. SERVICE LINES SHALL BE CTS POLYETHYLENE TUBING (CONFORMING TO SSPWC 203.16.02) WITH TUBING LINERS AS PER FITTING MANUFACTURER'S INSTRUCTIONS.
2. SHORT BODY "Y" SHALL BE MUELLER CTS 110 COMP H-15343N, FORD QUICK JOINT Y44-274-Q-NL OR APPROVED EQUAL. CONNECT TO PE TUBING WITH TUBING LINER PER DWG. C-3.2.1.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	DETAIL NAME	3/22	1" DUAL PIT SETTERS 1	CARSON CITY
				DRAWING NO. C-3.2.4 (203,307)
				DATE MAR 2022
APPROVED BY:		3/22		